




DEC	DEAD END CAP	—	WATER PIPE(SIZE AND CLASS AS SHOWN)
FH	FIRE HYDRANT	●	Ø100 PVC-U PN12 CONDUIT
SV	STOP VALVE	⊥	
W	WATER METER	⊕	
()	READY TAP	>	FITTING

NOTES:
 HORIZONTAL COORDINATES(E,N) SUPPLIED ARE MAPPING GRID OF AUSTRALIA(MGA), ZONE 56 BASED ON THE UNIVERSAL TRANSVERSE MERCATOR PROJECTION AND THE GEOCENTRIC DATUM OF AUSTRALIA 1994. HORIZONTAL DATUM DERIVED FROM PSM58130 E:4.79158,122 N: 6.938706,24.8 LEVELS SUPPLIED ARE ON THE AUSTRALIAN HEIGHT DATUM(AHD) LEVEL DATUM DERIVED FROM PSM58130 RL54.763(AHD)
 WATER SERVICE DETAILS -
 DN25 PE - LOTS 601,617 - 623,626 - 634,640,641
 DN32 PE - LOTS 612,635,638
 DN40 PE - LOTS 602 - 616,624 - 625,636 - 637,

REGISTERED SURVEYOR'S CERTIFICATION
 I, Gordon Nicholson, hereby certify that the vertical and horizontal locations and dimensions shown on this plan are a true and correct record and were located by survey.
 Registered Surveyor (sig) Reg. Surveyor No. SA 3405 Date: 21/10/2022

ENGINEER'S CERTIFICATION
 I, _____, hereby certify that:
 1. The information contained in this drawing / document is in compliance with approved drawings and design.
 2. The new water and sewerage works defined by this drawing have been designed and constructed in accordance with the SEQ Code.
 3. This represents an accurate record of as-constructed works.
 4. I accept responsibility for the information contained in this drawing / document.
 RPEQ (signature) RPEQ No. _____ Date: _____



A1										
	INDEX	DATE	REVISIONS	DRAWN	CHECKED	PASSED	INITIALS	DATE		
	A	21/10/2022	AS CONSTRUCTED	RDE	DAM	LR		21/10/2022		

DRAWN	RDE	21/10/2022
CHECKED	DAM	21/10/2022
PASSED	LR	21/10/2022



Queensland Urban Utilities
 QUU REF NO. 21-PNT-52533
 AS CONSTRUCTED SURVEY - WATER
 RIPLEY VALLEY, STAGE 11 & 12
 QLD

SHEET 1 OF 1 SHEETS	SCALE 1:300
REVISION DATE 21/10/2022	REVISION A
DISCIPLINE CODE -	
DRAWING NO. QUU-21-PNT-52533-W1-ST11	