



Stage 14 Allara Estate, Eglinton

Satterley Property Group

Bushfire Attack Level (BAL) Compliance and Certification Report

153,887 | 63145

15 December 2023



We acknowledge the Traditional Custodians of Country throughout Australia and their connections to land, sea and community.

We pay respect to Elders past and present and in the spirit of reconciliation, we commit to working together for our shared future.



Table of Contents

1. Introduction	3
1.1 Site summary.....	3
1.2 Purpose of report	3
2. Bushfire assessment results	5
2.1 Assessment inputs.....	5
2.1.1 Vegetation classification	5
2.1.2 Effective slope	5
2.1.3 Summary of inputs	5
2.2 Assessment outputs	7
2.2.1 Bushfire Attack Level (BAL) contour assessment.....	7
2.2.2 BAL certificates.....	7
3. Conclusion and recommendations	11
4. Limitations	12
5. References	13

List of Tables

Table 1: Site/development summary	3
Table 2: Summary of vegetation classifications, exclusions and effective slope	5
Table 3: BAL contour assessment results	8

List of Figures

Figure 1: Vegetation classification and effective slope	6
Figure 2: BAL contour map	10

Appendices

Appendix A BAL certificates

1. Introduction

1.1 Site summary

Table 1 provides a summary of the project area and proposed development. The development layout and subject lots are shown in Figure 1 and Figure 2.

Table 1: Site/development summary

Site details	
Address details	48 proposed residential lots within Stage 14 Allara Estate, Eglinton WA, 6034
Local government area	City of Wanneroo
Description of building works	Construction of a single residential dwelling (Class 1a building and associated Class 10a buildings) within each lot

1.2 Purpose of report

This Bushfire Attack Level (BAL) compliance and certification report has been prepared for 48 proposed residential lots within Stage 14 Allara Estate, Eglinton (hereafter referred to as the project area).

The project area is entirely designated bushfire prone on the Map of Bush Fire Prone Areas (DFES 2021, see Plate 1). As such, bushfire risk considerations and BAL assessment are applicable to all lots within the project area.

This report provides a post-subdivisional works update of the BAL ratings for individual lots within the project area and has been prepared for the benefit of the developer, future lot purchasers and decision makers. Due to the designated bushfire prone status of the entire project area, BAL certificates for all 48 proposed lots have been prepared based on a final site compliance check and are appended to this report for use at the building permit stage to facilitate future lot sales and building approvals (see Appendix A).

The BAL assessment outlined in this report has been prepared in consideration of the previous BAL contour assessment documented in the subdivision stage Bushfire Management Plan (BMP) prepared by Strategen (2018). The approach for preparation of this BAL compliance report is consistent with Section 4.2 and Appendix 3 of *Guidelines for Planning in Bushfire Prone Areas* (the Guidelines; WAPC 2021).

The BAL assessment outlined in this report is the most up to date assessment by JBS&G (formerly Strategen) relating to the project area and therefore supersedes any previous assessments undertaken for the project area by Strategen, Strategen-JBS&G and JBS&G, including those documented in the following previously prepared reports:

- Bushfire Management Plan for Allara Estate Stages 7–8 & 10–22, prepared by Strategen (2018)
- BAL Compliance and Certification report for the adjacent west Stage 22, prepared by JBS&G (2023).




Plate 1: Stage 14 designated bushfire prone status (DFES 2021)

2. Bushfire assessment results

2.1 Assessment inputs

2.1.1 Vegetation classification

JBS&G reassessed classified vegetation and exclusions within the 150 m assessment area through multiple site inspections and subsequent desktop validation on 9 November 2023 in accordance with AS 3959—2018 *Construction of Buildings in Bushfire-Prone Areas* (AS 3959; SA 2018) and the *Visual Guide for Bushfire Risk Assessment in Western Australia* (DoP 2016). Results are depicted in Figure 1, which clearly depict the project area and surrounding 150 m assessment area to be in an existing cleared, earthworked or constructed low threat state, as per the following exclusions under AS3959:

- the project area is in a cleared, non-vegetated state in preparation for development and is excluded from classification under Clauses 2.2.3.2 (e) and (f)
- adjacent stages of development (both existing and future) have either been constructed with residential dwellings or cleared and earthworked in preparation for development and are excluded from classification under Clauses 2.2.3.2 (e) and (f)
- the current POS cell adjacent southwest of the project area has been constructed to be excluded from classification under Clauses 2.2.3.2 (e) and (f).

2.1.2 Effective slope


Since no classified vegetation was identified within the project area or surrounding 150 m assessment area, effective slope under classified vegetation is not applicable to the BAL assessment in this instance.

2.1.3 Summary of inputs

Figure 1 illustrates the exclusions identified within the project area and surrounding 150 m assessment area, which are summarised in Table 2.

Table 2: Summary of vegetation classifications, exclusions and effective slope

Vegetation plot	Vegetation classification	Effective slope	Comments
1	Excluded – Non-vegetated and Low threat (Clause 2.2.3.2 [e] and [f])	N/A	Existing non-vegetated areas (i.e. roads, buildings, footpaths, driveways, sealed areas, cleared/earthworked land, etc) and low threat managed land (i.e. managed gardens, irrigated turf, POS, street verges, low threat staging buffers, etc).



Legend Project area 100m assessment area 150m assessment area Cadastral boundary Proposed lot layout Stage boundaries Future indicative lot layout on adjacent stages Vegetation classification Excluded under Clauses 2.2.3.2 (e) and (f) Topographic contours (mAHD) Minor road	Scale: 1:2,600 at A4 	Allara Estate Stage 14, Eglinton, WA
	Coord. Sys. GDA2020 MGA Zone 50 	VEGETATION CLASSIFICATION AND EFFECTIVE SLOPE
Job Number: 63145 Client: Satterley Property Group	FIGURE 1	
Version: A Drawn By: jcrute	Date: 21-Nov-2023 Checked By: ZC	

2.2 Assessment outputs

2.2.1 Bushfire Attack Level (BAL) contour assessment

JBS&G has undertaken a BAL contour assessment for the project area in accordance with Method 1 of AS3959 (see Figure 2). The Method 1 procedure incorporates the following factors:


- state adopted FDI 80 rating
- vegetation classification/exclusions
- effective slope
- distance maintained between proposed development areas and the classified vegetation.

The BAL contours are based on the current on-ground site conditions confirmed during assessment and results are detailed in Table 3 and illustrated in Figure 2.

2.2.2 BAL certificates

BAL certificates for all 48 designated bushfire prone lots are provided in Appendix A in accordance with BAL contour assessment results detailed in Table 3 and Figure 2.

Lot	Designated bushfire prone area	Plot No.	Vegetation classification	Effective slope	Separation distance (to lot boundary)	Highest BAL (to lot boundary)
748	Yes	Plot 1	Excluded – Non-vegetated and Low threat (Clause 2.2.3.2 [e] and [f])	N/A	N/A	BAL-Low
749	Yes	Plot 1	Excluded – Non-vegetated and Low threat (Clause 2.2.3.2 [e] and [f])	N/A	N/A	BAL-Low
1169	Yes	Plot 1	Excluded – Non-vegetated and Low threat (Clause 2.2.3.2 [e] and [f])	N/A	N/A	BAL-Low
1170	Yes	Plot 1	Excluded – Non-vegetated and Low threat (Clause 2.2.3.2 [e] and [f])	N/A	N/A	BAL-Low
1171	Yes	Plot 1	Excluded – Non-vegetated and Low threat (Clause 2.2.3.2 [e] and [f])	N/A	N/A	BAL-Low
1172	Yes	Plot 1	Excluded – Non-vegetated and Low threat (Clause 2.2.3.2 [e] and [f])	N/A	N/A	BAL-Low
1173	Yes	Plot 1	Excluded – Non-vegetated and Low threat (Clause 2.2.3.2 [e] and [f])	N/A	N/A	BAL-Low
1174	Yes	Plot 1	Excluded – Non-vegetated and Low threat (Clause 2.2.3.2 [e] and [f])	N/A	N/A	BAL-Low
1175	Yes	Plot 1	Excluded – Non-vegetated and Low threat (Clause 2.2.3.2 [e] and [f])	N/A	N/A	BAL-Low
1176	Yes	Plot 1	Excluded – Non-vegetated and Low threat (Clause 2.2.3.2 [e] and [f])	N/A	N/A	BAL-Low
1177	Yes	Plot 1	Excluded – Non-vegetated and Low threat (Clause 2.2.3.2 [e] and [f])	N/A	N/A	BAL-Low



- Legend**
- Project area
 - 100m assessment area
 - 150m assessment area
 - Cadastral boundary
 - Proposed lot layout
 - Stage boundaries
 - Future indicative lot layout on adjacent stages
 - BAL Low
 - Minor road

Scale: 1:2,600 at A4			
Coord. Sys. GDA2020 MGA Zone 50			
Job Number: 63145			
Client: Satterley Property Group			
Version: A	Date: 21-Nov-2023		
Drawn By: jcrute	Checked By: ZC		

Allara Estate Stage 14, Eglinton, WA

BAL CONTOUR MAP

FIGURE 2

3. Conclusion and recommendations

This BAL compliance report has been prepared for 48 proposed residential lots within Stage 14 Allara Estate to provide a final BAL assessment and certification for use at the building permit stage.

JBS&G can confirm that the existing BMP over the project area has been implemented throughout the duration of subdivisional works for Stage 14 lots and the adjacent land to achieve the BAL outcomes as intended. It was determined that all 48 proposed lots within Stage 14 required formal BAL assessment and certification due to their designated bushfire prone status. A BAL-Low rating was determined for all proposed lots following BAL assessment.

JBS&G considers that the BAL contour assessment and BAL certificates outlined in this report are accurate to facilitate future lots sales and building approvals.

4. Limitations

This report has been prepared for use by the client who has commissioned the works in accordance with the project brief only, and has been based in part on information obtained from the client and other parties.

The advice herein relates only to this project and all results conclusions and recommendations made should be reviewed by a competent person with experience in environmental investigations, before being used for any other purpose.

JBS&G accepts no liability for use or interpretation by any person or body other than the client who commissioned the works. This report should not be reproduced without prior approval by the client, or amended in any way without prior approval by JBS&G, and should not be relied upon by other parties, who should make their own enquires.

Sampling and chemical analysis of environmental media is based on appropriate guidance documents made and approved by the relevant regulatory authorities. Conclusions arising from the review and assessment of environmental data are based on the sampling and analysis considered appropriate based on the regulatory requirements.

Limited sampling and laboratory analyses were undertaken as part of the investigations undertaken, as described herein. Ground conditions between sampling locations and media may vary, and this should be considered when extrapolating between sampling points. Chemical analytes are based on the information detailed in the site history. Further chemicals or categories of chemicals may exist at the site, which were not identified in the site history and which may not be expected at the site.

Changes to the subsurface conditions may occur subsequent to the investigations described herein, through natural processes or through the intentional or accidental addition of contaminants. The conclusions and recommendations reached in this report are based on the information obtained at the time of the investigations.

This report does not provide a complete assessment of the environmental status of the site, and it is limited to the scope defined herein. Should information become available regarding conditions at the site including previously unknown sources of contamination, JBS&G reserves the right to review the report in the context of the additional information.

5. References

- Department of Fire and Emergency Services (DFES) 2021, *Map of Bush Fire Prone Areas*, [Online], Government of Western Australia, available from: <https://maps.slip.wa.gov.au/landgate/bushfireprone/>, [8/12/2023].
- Department of Planning (DoP) 2016, *Visual guide for bushfire risk assessment in Western Australia*, Department of Planning, Perth.
- JBS&G 2023, *Stage 22 Allara Estate, Eglinton, WA - Bushfire Attack Level (BAL) Compliance Report*, report prepared for Satterley Property Group, June 2023.
- Standards Australia (SA) 2018, *Australian Standard AS 3959–2018 Construction of Buildings in Bushfire-prone Areas*, Standards Australia, Sydney.
- Strategen Environmental (Strategen) 2018, *Bushfire Management Plan (Subdivision Application): Stages 7–8 & 10–22 Allara Estate, Eglinton*, report prepared for Satterley Property Group, November 2018.
- Western Australian Planning Commission (WAPC) 2021, *Guidelines for Planning in Bushfire Prone Areas, Version 1.4 December 2021*, Western Australian Planning Commission, Perth.

Appendix A BAL certificates

Bushfire Attack Level (BAL) Certificate

Determined in accordance with AS 3959-2018

This Certificate has been issued by a person accredited by Fire Protection Association Australia under the Bushfire Planning and Design (BPAD) Accreditation Scheme. The certificate details the conclusions of the full Bushfire Attack Level Assessment Report (full report) prepared by the Accredited Practitioner.


Property Details and Description of Works

Address Details	Unit no	Street no	Lot no	Street name / Plan Reference	
			38	Impressions Drive	
Local government area	Suburb			State	Postcode
	Eglinton			WA	6034
Main BCA class of the building	Class 1a	Use(s) of the building	Residential dwelling		
Description of the building or works	Construction of a single Class 1a building and associated Class 10a building/s				

Determination of Highest Bushfire Attack Level

AS 3959 Assessment Procedure	Vegetation Classification	Effective Slope	Separation Distance	BAL
Method 1	Excludable – Clause 2.2.3.2(f)	N/A	N/A	BAL – LOW

BPAD Accredited Practitioner Details

Name Zac Cockerill	<div style="border: 1px solid black; padding: 5px;"> <p>I hereby declare that I am a BPAD accredited bushfire practitioner. </p> <p>Accreditation No. <u>37803</u></p> <p>Signature <u><i>Zac Cockerill</i></u></p> <p>Date <u>15/12/23</u></p> </div>
Company Details JBS&G Australia Pty Ltd	
I hereby certify that I have undertaken the assessment of the above site and determined the Bushfire Attack Level stated above in accordance with the requirements of AS 3959-2018.	

Authorised Practitioner Stamp

Reliance on the assessment and determination of the Bushfire Attack Level contained in this certificate should not extend beyond a period of 12 months from the date of issue of the certificate. If this certificate was issued more than 12 months ago, it is recommended that the validity of the determination be confirmed with the Accredited Practitioner and where required an updated certificate issued.

Bushfire Attack Level (BAL) Certificate

Determined in accordance with AS 3959-2018

This Certificate has been issued by a person accredited by Fire Protection Association Australia under the Bushfire Planning and Design (BPAD) Accreditation Scheme. The certificate details the conclusions of the full Bushfire Attack Level Assessment Report (full report) prepared by the Accredited Practitioner.


Property Details and Description of Works

Address Details	Unit no	Street no	Lot no	Street name / Plan Reference	
			700	Impressions Drive	
Local government area	Suburb			State	Postcode
	Eglinton			WA	6034
Main BCA class of the building	Class 1a	Use(s) of the building	Residential dwelling		
Description of the building or works	Construction of a single Class 1a building and associated Class 10a building/s				

Determination of Highest Bushfire Attack Level

AS 3959 Assessment Procedure	Vegetation Classification	Effective Slope	Separation Distance	BAL
Method 1	Excludable – Clause 2.2.3.2(f)	N/A	N/A	BAL – LOW

BPAD Accredited Practitioner Details

Name Zac Cockerill	<div style="border: 1px solid black; padding: 5px;"> <p>I hereby declare that I am a BPAD accredited bushfire practitioner. </p> <p>Accreditation No. <u>37803</u></p> <p>Signature <u><i>ZC</i></u></p> <p>Date <u>15/12/23</u></p> </div>
Company Details JBS&G Australia Pty Ltd	
I hereby certify that I have undertaken the assessment of the above site and determined the Bushfire Attack Level stated above in accordance with the requirements of AS 3959-2018.	

Authorised Practitioner Stamp

Reliance on the assessment and determination of the Bushfire Attack Level contained in this certificate should not extend beyond a period of 12 months from the date of issue of the certificate. If this certificate was issued more than 12 months ago, it is recommended that the validity of the determination be confirmed with the Accredited Practitioner and where required an updated certificate issued.

Bushfire Attack Level (BAL) Certificate

Determined in accordance with AS 3959-2018

This Certificate has been issued by a person accredited by Fire Protection Association Australia under the Bushfire Planning and Design (BPAD) Accreditation Scheme. The certificate details the conclusions of the full Bushfire Attack Level Assessment Report (full report) prepared by the Accredited Practitioner.


Property Details and Description of Works

Address Details	Unit no	Street no	Lot no	Street name / Plan Reference	
			701	Impressions Drive	
Local government area	Suburb			State	Postcode
	Eglinton			WA	6034
Main BCA class of the building	Class 1a	Use(s) of the building	Residential dwelling		
Description of the building or works	Construction of a single Class 1a building and associated Class 10a building/s				

Determination of Highest Bushfire Attack Level

AS 3959 Assessment Procedure	Vegetation Classification	Effective Slope	Separation Distance	BAL
Method 1	Excludable – Clause 2.2.3.2(f)	N/A	N/A	BAL – LOW

BPAD Accredited Practitioner Details

Name Zac Cockerill	<div style="border: 1px solid black; padding: 5px;"> <p>I hereby declare that I am a BPAD accredited bushfire practitioner. </p> <p>Accreditation No. <u>37803</u></p> <p>Signature <u>[Signature]</u></p> <p>Date <u>15/12/23</u></p> </div> <p><i>Authorised Practitioner Stamp</i></p>
Company Details JBS&G Australia Pty Ltd	
I hereby certify that I have undertaken the assessment of the above site and determined the Bushfire Attack Level stated above in accordance with the requirements of AS 3959-2018.	

Reliance on the assessment and determination of the Bushfire Attack Level contained in this certificate should not extend beyond a period of 12 months from the date of issue of the certificate. If this certificate was issued more than 12 months ago, it is recommended that the validity of the determination be confirmed with the Accredited Practitioner and where required an updated certificate issued.

Bushfire Attack Level (BAL) Certificate

Determined in accordance with AS 3959-2018

This Certificate has been issued by a person accredited by Fire Protection Association Australia under the Bushfire Planning and Design (BPAD) Accreditation Scheme. The certificate details the conclusions of the full Bushfire Attack Level Assessment Report (full report) prepared by the Accredited Practitioner.


Property Details and Description of Works

Address Details	Unit no	Street no	Lot no	Street name / Plan Reference	
			702	Impressions Drive	
Local government area	Suburb			State	Postcode
	Eglinton			WA	6034
Main BCA class of the building	Class 1a	Use(s) of the building	Residential dwelling		
Description of the building or works	Construction of a single Class 1a building and associated Class 10a building/s				

Determination of Highest Bushfire Attack Level

AS 3959 Assessment Procedure	Vegetation Classification	Effective Slope	Separation Distance	BAL
Method 1	Excludable – Clause 2.2.3.2(f)	N/A	N/A	BAL – LOW

BPAD Accredited Practitioner Details

Name Zac Cockerill	<div style="border: 1px solid black; padding: 5px;"> <p>I hereby declare that I am a BPAD accredited bushfire practitioner. </p> <p>Accreditation No. <u>37803</u></p> <p>Signature <u><i>ZC</i></u></p> <p>Date <u>15/12/23</u></p> </div> <p><i>Authorised Practitioner Stamp</i></p>
Company Details JBS&G Australia Pty Ltd	
I hereby certify that I have undertaken the assessment of the above site and determined the Bushfire Attack Level stated above in accordance with the requirements of AS 3959-2018.	

Reliance on the assessment and determination of the Bushfire Attack Level contained in this certificate should not extend beyond a period of 12 months from the date of issue of the certificate. If this certificate was issued more than 12 months ago, it is recommended that the validity of the determination be confirmed with the Accredited Practitioner and where required an updated certificate issued.

Bushfire Attack Level (BAL) Certificate

Determined in accordance with AS 3959-2018

This Certificate has been issued by a person accredited by Fire Protection Association Australia under the Bushfire Planning and Design (BPAD) Accreditation Scheme. The certificate details the conclusions of the full Bushfire Attack Level Assessment Report (full report) prepared by the Accredited Practitioner.


Property Details and Description of Works

Address Details	Unit no	Street no	Lot no	Street name / Plan Reference	
			703	Impressions Drive	
Local government area	Suburb			State	Postcode
	Eglinton			WA	6034
Main BCA class of the building	Class 1a	Use(s) of the building	Residential dwelling		
Description of the building or works	Construction of a single Class 1a building and associated Class 10a building/s				

Determination of Highest Bushfire Attack Level

AS 3959 Assessment Procedure	Vegetation Classification	Effective Slope	Separation Distance	BAL
Method 1	Excludable – Clause 2.2.3.2(f)	N/A	N/A	BAL – LOW

BPAD Accredited Practitioner Details

Name Zac Cockerill	<div style="border: 1px solid black; padding: 5px;"> <p>I hereby declare that I am a BPAD accredited bushfire practitioner. </p> <p>Accreditation No. <u>37803</u></p> <p>Signature <u>[Signature]</u></p> <p>Date <u>15/12/23</u></p> </div> <p><i>Authorised Practitioner Stamp</i></p>
Company Details JBS&G Australia Pty Ltd	
I hereby certify that I have undertaken the assessment of the above site and determined the Bushfire Attack Level stated above in accordance with the requirements of AS 3959-2018.	

Reliance on the assessment and determination of the Bushfire Attack Level contained in this certificate should not extend beyond a period of 12 months from the date of issue of the certificate. If this certificate was issued more than 12 months ago, it is recommended that the validity of the determination be confirmed with the Accredited Practitioner and where required an updated certificate issued.

Bushfire Attack Level (BAL) Certificate

Determined in accordance with AS 3959-2018

This Certificate has been issued by a person accredited by Fire Protection Association Australia under the Bushfire Planning and Design (BPAD) Accreditation Scheme. The certificate details the conclusions of the full Bushfire Attack Level Assessment Report (full report) prepared by the Accredited Practitioner.


Property Details and Description of Works

Address Details	Unit no	Street no	Lot no	Street name / Plan Reference	
			704	Impressions Drive	
Local government area	Suburb			State	Postcode
	Eglinton			WA	6034
Main BCA class of the building	Use(s) of the building		Residential dwelling		
Description of the building or works	Construction of a single Class 1a building and associated Class 10a building/s				

Determination of Highest Bushfire Attack Level

AS 3959 Assessment Procedure	Vegetation Classification	Effective Slope	Separation Distance	BAL
Method 1	Excludable – Clause 2.2.3.2(f)	N/A	N/A	BAL – LOW

BPAD Accredited Practitioner Details

Name Zac Cockerill	 <p>I hereby declare that I am a BPAD accredited bushfire practitioner.</p> <p>Accreditation No. 37803</p> <p>Signature <i>[Signature]</i></p> <p>Date 15/12/23</p>
Company Details JBS&G Australia Pty Ltd	
I hereby certify that I have undertaken the assessment of the above site and determined the Bushfire Attack Level stated above in accordance with the requirements of AS 3959-2018.	

Authorised Practitioner Stamp

Reliance on the assessment and determination of the Bushfire Attack Level contained in this certificate should not extend beyond a period of 12 months from the date of issue of the certificate. If this certificate was issued more than 12 months ago, it is recommended that the validity of the determination be confirmed with the Accredited Practitioner and where required an updated certificate issued.

Bushfire Attack Level (BAL) Certificate

Determined in accordance with AS 3959-2018

This Certificate has been issued by a person accredited by Fire Protection Association Australia under the Bushfire Planning and Design (BPAD) Accreditation Scheme. The certificate details the conclusions of the full Bushfire Attack Level Assessment Report (full report) prepared by the Accredited Practitioner.


Property Details and Description of Works

Address Details	Unit no	Street no	Lot no	Street name / Plan Reference	
			705	Impressions Drive	
Local government area	Suburb			State	Postcode
	Eglinton			WA	6034
Main BCA class of the building	Class 1a	Use(s) of the building	Residential dwelling		
Description of the building or works	Construction of a single Class 1a building and associated Class 10a building/s				

Determination of Highest Bushfire Attack Level

AS 3959 Assessment Procedure	Vegetation Classification	Effective Slope	Separation Distance	BAL
Method 1	Excludable – Clause 2.2.3.2(f)	N/A	N/A	BAL – LOW

BPAD Accredited Practitioner Details

Name Zac Cockerill	 <p>I hereby declare that I am a BPAD accredited bushfire practitioner.</p> <p>Accreditation No. 37803</p> <p>Signature <i>[Signature]</i></p> <p>Date 15/12/23</p>
Company Details JBS&G Australia Pty Ltd	
I hereby certify that I have undertaken the assessment of the above site and determined the Bushfire Attack Level stated above in accordance with the requirements of AS 3959-2018.	

Authorised Practitioner Stamp

Reliance on the assessment and determination of the Bushfire Attack Level contained in this certificate should not extend beyond a period of 12 months from the date of issue of the certificate. If this certificate was issued more than 12 months ago, it is recommended that the validity of the determination be confirmed with the Accredited Practitioner and where required an updated certificate issued.

Bushfire Attack Level (BAL) Certificate

Determined in accordance with AS 3959-2018

This Certificate has been issued by a person accredited by Fire Protection Association Australia under the Bushfire Planning and Design (BPAD) Accreditation Scheme. The certificate details the conclusions of the full Bushfire Attack Level Assessment Report (full report) prepared by the Accredited Practitioner.


Property Details and Description of Works

Address Details	Unit no	Street no	Lot no	Street name / Plan Reference	
			706	Impressions Drive	
Local government area	Suburb			State	Postcode
	Eglinton			WA	6034
	City of Wanneroo				
Main BCA class of the building	Class 1a	Use(s) of the building	Residential dwelling		
Description of the building or works	Construction of a single Class 1a building and associated Class 10a building/s				

Determination of Highest Bushfire Attack Level

AS 3959 Assessment Procedure	Vegetation Classification	Effective Slope	Separation Distance	BAL
Method 1	Excludable – Clause 2.2.3.2(f)	N/A	N/A	BAL – LOW

BPAD Accredited Practitioner Details

Name Zac Cockerill	 <p>I hereby declare that I am a BPAD accredited bushfire practitioner.</p> <p>Accreditation No. 37805</p> <p>Signature <i>[Signature]</i></p> <p>Date 15/12/23</p>
Company Details JBS&G Australia Pty Ltd	
I hereby certify that I have undertaken the assessment of the above site and determined the Bushfire Attack Level stated above in accordance with the requirements of AS 3959-2018.	

Authorised Practitioner Stamp

Reliance on the assessment and determination of the Bushfire Attack Level contained in this certificate should not extend beyond a period of 12 months from the date of issue of the certificate. If this certificate was issued more than 12 months ago, it is recommended that the validity of the determination be confirmed with the Accredited Practitioner and where required an updated certificate issued.

Bushfire Attack Level (BAL) Certificate

Determined in accordance with AS 3959-2018

This Certificate has been issued by a person accredited by Fire Protection Association Australia under the Bushfire Planning and Design (BPAD) Accreditation Scheme. The certificate details the conclusions of the full Bushfire Attack Level Assessment Report (full report) prepared by the Accredited Practitioner.


Property Details and Description of Works

Address Details	Unit no	Street no	Lot no	Street name / Plan Reference	
			707	Impressions Drive	
Local government area	Suburb			State	Postcode
	Eglinton			WA	6034
Main BCA class of the building	Class 1a	Use(s) of the building	Residential dwelling		
Description of the building or works	Construction of a single Class 1a building and associated Class 10a building/s				

Determination of Highest Bushfire Attack Level

AS 3959 Assessment Procedure	Vegetation Classification	Effective Slope	Separation Distance	BAL
Method 1	Excludable – Clause 2.2.3.2(f)	N/A	N/A	BAL – LOW

BPAD Accredited Practitioner Details

Name Zac Cockerill	<div style="border: 1px solid black; padding: 5px;"> <p>I hereby declare that I am a BPAD accredited bushfire practitioner. </p> <p>Accreditation No. <u>37803</u></p> <p>Signature <u>[Signature]</u></p> <p>Date <u>15/12/23</u></p> </div>
Company Details JBS&G Australia Pty Ltd	
I hereby certify that I have undertaken the assessment of the above site and determined the Bushfire Attack Level stated above in accordance with the requirements of AS 3959-2018.	

Authorised Practitioner Stamp

Reliance on the assessment and determination of the Bushfire Attack Level contained in this certificate should not extend beyond a period of 12 months from the date of issue of the certificate. If this certificate was issued more than 12 months ago, it is recommended that the validity of the determination be confirmed with the Accredited Practitioner and where required an updated certificate issued.

Bushfire Attack Level (BAL) Certificate

Determined in accordance with AS 3959-2018

This Certificate has been issued by a person accredited by Fire Protection Association Australia under the Bushfire Planning and Design (BPAD) Accreditation Scheme. The certificate details the conclusions of the full Bushfire Attack Level Assessment Report (full report) prepared by the Accredited Practitioner.


Property Details and Description of Works

Address Details	Unit no	Street no	Lot no	Street name / Plan Reference	
			708	Impressions Drive	
Local government area	Suburb			State	Postcode
	Eglinton			WA	6034
Main BCA class of the building	Use(s) of the building		Residential dwelling		
Description of the building or works	Construction of a single Class 1a building and associated Class 10a building/s				

Determination of Highest Bushfire Attack Level

AS 3959 Assessment Procedure	Vegetation Classification	Effective Slope	Separation Distance	BAL
Method 1	Excludable – Clause 2.2.3.2(f)	N/A	N/A	BAL – LOW

BPAD Accredited Practitioner Details

Name Zac Cockerill	 <p><i>Authorised Practitioner Stamp</i></p>
Company Details JBS&G Australia Pty Ltd	
I hereby certify that I have undertaken the assessment of the above site and determined the Bushfire Attack Level stated above in accordance with the requirements of AS 3959-2018.	

Reliance on the assessment and determination of the Bushfire Attack Level contained in this certificate should not extend beyond a period of 12 months from the date of issue of the certificate. If this certificate was issued more than 12 months ago, it is recommended that the validity of the determination be confirmed with the Accredited Practitioner and where required an updated certificate issued.

Bushfire Attack Level (BAL) Certificate

Determined in accordance with AS 3959-2018

This Certificate has been issued by a person accredited by Fire Protection Association Australia under the Bushfire Planning and Design (BPAD) Accreditation Scheme. The certificate details the conclusions of the full Bushfire Attack Level Assessment Report (full report) prepared by the Accredited Practitioner.


Property Details and Description of Works

Address Details	Unit no	Street no	Lot no	Street name / Plan Reference	
			709	Impressions Drive	
Local government area	Suburb			State	Postcode
	Eglinton			WA	6034
Main BCA class of the building	Class 1a	Use(s) of the building	Residential dwelling		
Description of the building or works	Construction of a single Class 1a building and associated Class 10a building/s				

Determination of Highest Bushfire Attack Level

AS 3959 Assessment Procedure	Vegetation Classification	Effective Slope	Separation Distance	BAL
Method 1	Excludable – Clause 2.2.3.2(f)	N/A	N/A	BAL – LOW

BPAD Accredited Practitioner Details

Name Zac Cockerill	<div style="border: 1px solid black; padding: 5px;"> <p>I hereby declare that I am a BPAD accredited bushfire practitioner. </p> <p>Accreditation No. <u>37803</u></p> <p>Signature <u>[Signature]</u></p> <p>Date <u>15/12/23</u></p> </div> <p><i>Authorised Practitioner Stamp</i></p>
Company Details JBS&G Australia Pty Ltd	
I hereby certify that I have undertaken the assessment of the above site and determined the Bushfire Attack Level stated above in accordance with the requirements of AS 3959-2018.	

Reliance on the assessment and determination of the Bushfire Attack Level contained in this certificate should not extend beyond a period of 12 months from the date of issue of the certificate. If this certificate was issued more than 12 months ago, it is recommended that the validity of the determination be confirmed with the Accredited Practitioner and where required an updated certificate issued.

Bushfire Attack Level (BAL) Certificate

Determined in accordance with AS 3959-2018

This Certificate has been issued by a person accredited by Fire Protection Association Australia under the Bushfire Planning and Design (BPAD) Accreditation Scheme. The certificate details the conclusions of the full Bushfire Attack Level Assessment Report (full report) prepared by the Accredited Practitioner.


Property Details and Description of Works

Address Details	Unit no	Street no	Lot no	Street name / Plan Reference	
			710	Impressions Drive	
Local government area	Suburb			State	Postcode
	Eglinton			WA	6034
Main BCA class of the building	Class 1a	Use(s) of the building	Residential dwelling		
Description of the building or works	Construction of a single Class 1a building and associated Class 10a building/s				

Determination of Highest Bushfire Attack Level

AS 3959 Assessment Procedure	Vegetation Classification	Effective Slope	Separation Distance	BAL
Method 1	Excludable – Clause 2.2.3.2(f)	N/A	N/A	BAL – LOW

BPAD Accredited Practitioner Details

Name Zac Cockerill	<div style="border: 1px solid black; padding: 5px;"> <p>I hereby declare that I am a BPAD accredited bushfire practitioner. </p> <p>Accreditation No. <u>37803</u></p> <p>Signature <u>[Signature]</u></p> <p>Date <u>15/12/23</u></p> </div>
Company Details JBS&G Australia Pty Ltd	
I hereby certify that I have undertaken the assessment of the above site and determined the Bushfire Attack Level stated above in accordance with the requirements of AS 3959-2018.	

Authorised Practitioner Stamp

Reliance on the assessment and determination of the Bushfire Attack Level contained in this certificate should not extend beyond a period of 12 months from the date of issue of the certificate. If this certificate was issued more than 12 months ago, it is recommended that the validity of the determination be confirmed with the Accredited Practitioner and where required an updated certificate issued.

Bushfire Attack Level (BAL) Certificate

Determined in accordance with AS 3959-2018

This Certificate has been issued by a person accredited by Fire Protection Association Australia under the Bushfire Planning and Design (BPAD) Accreditation Scheme. The certificate details the conclusions of the full Bushfire Attack Level Assessment Report (full report) prepared by the Accredited Practitioner.


Property Details and Description of Works

Address Details	Unit no	Street no	Lot no	Street name / Plan Reference	
			711	Impressions Drive	
Local government area	Suburb			State	Postcode
	Eglinton			WA	6034
Main BCA class of the building	Class 1a	Use(s) of the building	Residential dwelling		
Description of the building or works	Construction of a single Class 1a building and associated Class 10a building/s				

Determination of Highest Bushfire Attack Level

AS 3959 Assessment Procedure	Vegetation Classification	Effective Slope	Separation Distance	BAL
Method 1	Excludable – Clause 2.2.3.2(f)	N/A	N/A	BAL – LOW

BPAD Accredited Practitioner Details

Name Zac Cockerill	 <p>I hereby declare that I am a BPAD accredited bushfire practitioner. Accreditation No. 37803 Signature <i>ZC</i> Date 15/12/23</p>
Company Details JBS&G Australia Pty Ltd	
I hereby certify that I have undertaken the assessment of the above site and determined the Bushfire Attack Level stated above in accordance with the requirements of AS 3959-2018.	

Authorised Practitioner Stamp

Reliance on the assessment and determination of the Bushfire Attack Level contained in this certificate should not extend beyond a period of 12 months from the date of issue of the certificate. If this certificate was issued more than 12 months ago, it is recommended that the validity of the determination be confirmed with the Accredited Practitioner and where required an updated certificate issued.

Bushfire Attack Level (BAL) Certificate

Determined in accordance with AS 3959-2018

This Certificate has been issued by a person accredited by Fire Protection Association Australia under the Bushfire Planning and Design (BPAD) Accreditation Scheme. The certificate details the conclusions of the full Bushfire Attack Level Assessment Report (full report) prepared by the Accredited Practitioner.


Property Details and Description of Works

Address Details	Unit no	Street no	Lot no	Street name / Plan Reference	
			712	Impressions Drive	
Local government area	Suburb			State	Postcode
	Eglinton			WA	6034
Main BCA class of the building	Class 1a	Use(s) of the building	Residential dwelling		
Description of the building or works	Construction of a single Class 1a building and associated Class 10a building/s				

Determination of Highest Bushfire Attack Level

AS 3959 Assessment Procedure	Vegetation Classification	Effective Slope	Separation Distance	BAL
Method 1	Excludable – Clause 2.2.3.2(f)	N/A	N/A	BAL – LOW

BPAD Accredited Practitioner Details

Name Zac Cockerill	<div style="border: 1px solid black; padding: 5px;"> <p>I hereby declare that I am a BPAD accredited bushfire practitioner. </p> <p>Accreditation No. <u>37803</u></p> <p>Signature <u><i>ZC</i></u></p> <p>Date <u>15/12/23</u></p> </div>
Company Details JBS&G Australia Pty Ltd	
I hereby certify that I have undertaken the assessment of the above site and determined the Bushfire Attack Level stated above in accordance with the requirements of AS 3959-2018.	

Authorised Practitioner Stamp

Reliance on the assessment and determination of the Bushfire Attack Level contained in this certificate should not extend beyond a period of 12 months from the date of issue of the certificate. If this certificate was issued more than 12 months ago, it is recommended that the validity of the determination be confirmed with the Accredited Practitioner and where required an updated certificate issued.

Bushfire Attack Level (BAL) Certificate

Determined in accordance with AS 3959-2018

This Certificate has been issued by a person accredited by Fire Protection Association Australia under the Bushfire Planning and Design (BPAD) Accreditation Scheme. The certificate details the conclusions of the full Bushfire Attack Level Assessment Report (full report) prepared by the Accredited Practitioner.


Property Details and Description of Works

Address Details	Unit no	Street no	Lot no	Street name / Plan Reference	
			713	Impressions Drive	
Local government area	Suburb			State	Postcode
	Eglinton			WA	6034
Main BCA class of the building	Class 1a	Use(s) of the building	Residential dwelling		
Description of the building or works	Construction of a single Class 1a building and associated Class 10a building/s				

Determination of Highest Bushfire Attack Level

AS 3959 Assessment Procedure	Vegetation Classification	Effective Slope	Separation Distance	BAL
Method 1	Excludable – Clause 2.2.3.2(f)	N/A	N/A	BAL – LOW

BPAD Accredited Practitioner Details

Name Zac Cockerill	<div style="border: 1px solid black; padding: 5px;"> <p>I hereby declare that I am a BPAD accredited bushfire practitioner. </p> <p>Accreditation No. <u>37803</u></p> <p>Signature <u><i>ZC</i></u></p> <p>Date <u>15/12/23</u></p> </div>
Company Details JBS&G Australia Pty Ltd	
I hereby certify that I have undertaken the assessment of the above site and determined the Bushfire Attack Level stated above in accordance with the requirements of AS 3959-2018.	

Authorised Practitioner Stamp

Reliance on the assessment and determination of the Bushfire Attack Level contained in this certificate should not extend beyond a period of 12 months from the date of issue of the certificate. If this certificate was issued more than 12 months ago, it is recommended that the validity of the determination be confirmed with the Accredited Practitioner and where required an updated certificate issued.

Bushfire Attack Level (BAL) Certificate

Determined in accordance with AS 3959-2018

This Certificate has been issued by a person accredited by Fire Protection Association Australia under the Bushfire Planning and Design (BPAD) Accreditation Scheme. The certificate details the conclusions of the full Bushfire Attack Level Assessment Report (full report) prepared by the Accredited Practitioner.


Property Details and Description of Works

Address Details	Unit no	Street no	Lot no 714	Street name / Plan Reference Impressions Drive	
	Suburb Eglinton			State WA	Postcode 6034
Local government area	City of Wanneroo				
Main BCA class of the building	Class 1a	Use(s) of the building	Residential dwelling		
Description of the building or works	Construction of a single Class 1a building and associated Class 10a building/s				

Determination of Highest Bushfire Attack Level

AS 3959 Assessment Procedure	Vegetation Classification	Effective Slope	Separation Distance	BAL
Method 1	Excludable – Clause 2.2.3.2(f)	N/A	N/A	BAL – LOW

BPAD Accredited Practitioner Details

Name Zac Cockerill	 <p>I hereby declare that I am a BPAD accredited bushfire practitioner.</p> <p>Accreditation No. 37803</p> <p>Signature <i>ZC</i></p> <p>Date 15/12/23</p>
Company Details JBS&G Australia Pty Ltd	
I hereby certify that I have undertaken the assessment of the above site and determined the Bushfire Attack Level stated above in accordance with the requirements of AS 3959-2018.	

Authorised Practitioner Stamp

Reliance on the assessment and determination of the Bushfire Attack Level contained in this certificate should not extend beyond a period of 12 months from the date of issue of the certificate. If this certificate was issued more than 12 months ago, it is recommended that the validity of the determination be confirmed with the Accredited Practitioner and where required an updated certificate issued.

Bushfire Attack Level (BAL) Certificate

Determined in accordance with AS 3959-2018

This Certificate has been issued by a person accredited by Fire Protection Association Australia under the Bushfire Planning and Design (BPAD) Accreditation Scheme. The certificate details the conclusions of the full Bushfire Attack Level Assessment Report (full report) prepared by the Accredited Practitioner.


Property Details and Description of Works

Address Details	Unit no	Street no	Lot no	Street name / Plan Reference	
			715	Bonfire Chase	
Local government area	Suburb			State	Postcode
	Eglinton			WA	6034
Main BCA class of the building	Class 1a	Use(s) of the building	Residential dwelling		
Description of the building or works	Construction of a single Class 1a building and associated Class 10a building/s				

Determination of Highest Bushfire Attack Level

AS 3959 Assessment Procedure	Vegetation Classification	Effective Slope	Separation Distance	BAL
Method 1	Excludable – Clause 2.2.3.2(f)	N/A	N/A	BAL – LOW

BPAD Accredited Practitioner Details

Name Zac Cockerill	<div style="border: 1px solid black; padding: 5px;"> <p>I hereby declare that I am a BPAD accredited bushfire practitioner. </p> <p>Accreditation No. <u>37813</u></p> <p>Signature <u>[Signature]</u></p> <p>Date <u>15/12/23</u></p> </div>
Company Details JBS&G Australia Pty Ltd	
I hereby certify that I have undertaken the assessment of the above site and determined the Bushfire Attack Level stated above in accordance with the requirements of AS 3959-2018.	

Authorised Practitioner Stamp

Reliance on the assessment and determination of the Bushfire Attack Level contained in this certificate should not extend beyond a period of 12 months from the date of issue of the certificate. If this certificate was issued more than 12 months ago, it is recommended that the validity of the determination be confirmed with the Accredited Practitioner and where required an updated certificate issued.

Bushfire Attack Level (BAL) Certificate

Determined in accordance with AS 3959-2018

This Certificate has been issued by a person accredited by Fire Protection Association Australia under the Bushfire Planning and Design (BPAD) Accreditation Scheme. The certificate details the conclusions of the full Bushfire Attack Level Assessment Report (full report) prepared by the Accredited Practitioner.


Property Details and Description of Works

Address Details	Unit no	Street no	Lot no	Street name / Plan Reference	
			716	Bonfire Chase	
Local government area	Suburb			State	Postcode
	Eglinton			WA	6034
Main BCA class of the building	Class 1a	Use(s) of the building	Residential dwelling		
Description of the building or works	Construction of a single Class 1a building and associated Class 10a building/s				

Determination of Highest Bushfire Attack Level

AS 3959 Assessment Procedure	Vegetation Classification	Effective Slope	Separation Distance	BAL
Method 1	Excludable – Clause 2.2.3.2(f)	N/A	N/A	BAL – LOW

BPAD Accredited Practitioner Details

Name Zac Cockerill	<div style="border: 1px solid black; padding: 5px;"> <p>I hereby declare that I am a BPAD accredited bushfire practitioner. </p> <p>Accreditation No. <u>37803</u></p> <p>Signature <u><i>ZC</i></u></p> <p>Date <u>15/12/23</u></p> </div> <p><i>Authorised Practitioner Stamp</i></p>
Company Details JBS&G Australia Pty Ltd	
I hereby certify that I have undertaken the assessment of the above site and determined the Bushfire Attack Level stated above in accordance with the requirements of AS 3959-2018.	

Reliance on the assessment and determination of the Bushfire Attack Level contained in this certificate should not extend beyond a period of 12 months from the date of issue of the certificate. If this certificate was issued more than 12 months ago, it is recommended that the validity of the determination be confirmed with the Accredited Practitioner and where required an updated certificate issued.

Bushfire Attack Level (BAL) Certificate

Determined in accordance with AS 3959-2018

This Certificate has been issued by a person accredited by Fire Protection Association Australia under the Bushfire Planning and Design (BPAD) Accreditation Scheme. The certificate details the conclusions of the full Bushfire Attack Level Assessment Report (full report) prepared by the Accredited Practitioner.


Property Details and Description of Works

Address Details	Unit no	Street no	Lot no	Street name / Plan Reference	
			717	Bonfire Chase	
Local government area	Suburb			State	Postcode
	Eglinton			WA	6034
Main BCA class of the building	Class 1a	Use(s) of the building	Residential dwelling		
Description of the building or works	Construction of a single Class 1a building and associated Class 10a building/s				

Determination of Highest Bushfire Attack Level

AS 3959 Assessment Procedure	Vegetation Classification	Effective Slope	Separation Distance	BAL
Method 1	Excludable – Clause 2.2.3.2(f)	N/A	N/A	BAL – LOW

BPAD Accredited Practitioner Details

Name Zac Cockerill	<div style="border: 1px solid black; padding: 5px;"> <p>I hereby declare that I am a BPAD accredited bushfire practitioner. </p> <p>Accreditation No. <u>37803</u></p> <p>Signature <u><i>Zac Cockerill</i></u></p> <p>Date <u>15/12/23</u></p> </div>
Company Details JBS&G Australia Pty Ltd	
I hereby certify that I have undertaken the assessment of the above site and determined the Bushfire Attack Level stated above in accordance with the requirements of AS 3959-2018.	

Authorised Practitioner Stamp

Reliance on the assessment and determination of the Bushfire Attack Level contained in this certificate should not extend beyond a period of 12 months from the date of issue of the certificate. If this certificate was issued more than 12 months ago, it is recommended that the validity of the determination be confirmed with the Accredited Practitioner and where required an updated certificate issued.

Bushfire Attack Level (BAL) Certificate

Determined in accordance with AS 3959-2018

This Certificate has been issued by a person accredited by Fire Protection Association Australia under the Bushfire Planning and Design (BPAD) Accreditation Scheme. The certificate details the conclusions of the full Bushfire Attack Level Assessment Report (full report) prepared by the Accredited Practitioner.



Property Details and Description of Works

Address Details	Unit no	Street no	Lot no	Street name / Plan Reference	
			718	Bonfire Chase	
Local government area	Suburb			State	Postcode
	Eglinton			WA	6034
Main BCA class of the building	Use(s) of the building				
Class 1a	Residential dwelling				
Description of the building or works	Construction of a single Class 1a building and associated Class 10a building/s				

Determination of Highest Bushfire Attack Level

AS 3959 Assessment Procedure	Vegetation Classification	Effective Slope	Separation Distance	BAL
Method 1	Excludable – Clause 2.2.3.2(f)	N/A	N/A	BAL – LOW

BPAD Accredited Practitioner Details

Name Zac Cockerill	<div style="border: 1px solid black; padding: 5px;"> <p>I hereby declare that I am a BPAD accredited bushfire practitioner. </p> <p>Accreditation No. 37803</p> <p>Signature </p> <p>Date 15/12/23</p> </div>
Company Details JBS&G Australia Pty Ltd	
I hereby certify that I have undertaken the assessment of the above site and determined the Bushfire Attack Level stated above in accordance with the requirements of AS 3959-2018.	

Authorised Practitioner Stamp

Reliance on the assessment and determination of the Bushfire Attack Level contained in this certificate should not extend beyond a period of 12 months from the date of issue of the certificate. If this certificate was issued more than 12 months ago, it is recommended that the validity of the determination be confirmed with the Accredited Practitioner and where required an updated certificate issued.

Bushfire Attack Level (BAL) Certificate

Determined in accordance with AS 3959-2018

This Certificate has been issued by a person accredited by Fire Protection Association Australia under the Bushfire Planning and Design (BPAD) Accreditation Scheme. The certificate details the conclusions of the full Bushfire Attack Level Assessment Report (full report) prepared by the Accredited Practitioner.


Property Details and Description of Works

Address Details	Unit no	Street no	Lot no	Street name / Plan Reference	
			719	Bonfire Chase	
Local government area	Suburb			State	Postcode
	Eglinton			WA	6034
Main BCA class of the building	Class 1a	Use(s) of the building	Residential dwelling		
Description of the building or works	Construction of a single Class 1a building and associated Class 10a building/s				

Determination of Highest Bushfire Attack Level

AS 3959 Assessment Procedure	Vegetation Classification	Effective Slope	Separation Distance	BAL
Method 1	Excludable – Clause 2.2.3.2(f)	N/A	N/A	BAL – LOW

BPAD Accredited Practitioner Details

Name Zac Cockerill	<div style="border: 1px solid black; padding: 5px;"> <p>I hereby declare that I am a BPAD accredited bushfire practitioner. </p> <p>Accreditation No. <u>37803</u></p> <p>Signature <u><i>Zac Cockerill</i></u></p> <p>Date <u>15/12/23</u></p> </div> <p><i>Authorised Practitioner Stamp</i></p>
Company Details JBS&G Australia Pty Ltd	
I hereby certify that I have undertaken the assessment of the above site and determined the Bushfire Attack Level stated above in accordance with the requirements of AS 3959-2018.	

Reliance on the assessment and determination of the Bushfire Attack Level contained in this certificate should not extend beyond a period of 12 months from the date of issue of the certificate. If this certificate was issued more than 12 months ago, it is recommended that the validity of the determination be confirmed with the Accredited Practitioner and where required an updated certificate issued.

Bushfire Attack Level (BAL) Certificate

Determined in accordance with AS 3959-2018

This Certificate has been issued by a person accredited by Fire Protection Association Australia under the Bushfire Planning and Design (BPAD) Accreditation Scheme. The certificate details the conclusions of the full Bushfire Attack Level Assessment Report (full report) prepared by the Accredited Practitioner.


Property Details and Description of Works

Address Details	Unit no	Street no	Lot no	Street name / Plan Reference	
			720	Bonfire Chase	
Local government area	Suburb			State	Postcode
	Eglinton			WA	6034
Main BCA class of the building	Class 1a	Use(s) of the building	Residential dwelling		
Description of the building or works	Construction of a single Class 1a building and associated Class 10a building/s				

Determination of Highest Bushfire Attack Level

AS 3959 Assessment Procedure	Vegetation Classification	Effective Slope	Separation Distance	BAL
Method 1	Excludable – Clause 2.2.3.2(f)	N/A	N/A	BAL – LOW

BPAD Accredited Practitioner Details

Name Zac Cockerill	<div style="border: 1px solid black; padding: 5px;"> <p>I hereby declare that I am a BPAD accredited bushfire practitioner. </p> <p>Accreditation No. <u>37803</u></p> <p>Signature <u>[Signature]</u></p> <p>Date <u>15/12/23</u></p> </div> <p><i>Authorised Practitioner Stamp</i></p>
Company Details JBS&G Australia Pty Ltd	
I hereby certify that I have undertaken the assessment of the above site and determined the Bushfire Attack Level stated above in accordance with the requirements of AS 3959-2018.	

Reliance on the assessment and determination of the Bushfire Attack Level contained in this certificate should not extend beyond a period of 12 months from the date of issue of the certificate. If this certificate was issued more than 12 months ago, it is recommended that the validity of the determination be confirmed with the Accredited Practitioner and where required an updated certificate issued.

Bushfire Attack Level (BAL) Certificate

Determined in accordance with AS 3959-2018

This Certificate has been issued by a person accredited by Fire Protection Association Australia under the Bushfire Planning and Design (BPAD) Accreditation Scheme. The certificate details the conclusions of the full Bushfire Attack Level Assessment Report (full report) prepared by the Accredited Practitioner.


Property Details and Description of Works

Address Details	Unit no	Street no	Lot no	Street name / Plan Reference	
			721	Bonfire Chase	
Local government area	Suburb			State	Postcode
	Eglinton			WA	6034
Main BCA class of the building	Class 1a	Use(s) of the building	Residential dwelling		
Description of the building or works	Construction of a single Class 1a building and associated Class 10a building/s				

Determination of Highest Bushfire Attack Level

AS 3959 Assessment Procedure	Vegetation Classification	Effective Slope	Separation Distance	BAL
Method 1	Excludable – Clause 2.2.3.2(f)	N/A	N/A	BAL – LOW

BPAD Accredited Practitioner Details

Name Zac Cockerill	<div style="border: 1px solid black; padding: 5px;"> <p>I hereby declare that I am a BPAD accredited bushfire practitioner. </p> <p>Accreditation No. <u>37803</u></p> <p>Signature <u>ZC</u></p> <p>Date <u>015/12/23</u></p> </div> <p><i>Authorised Practitioner Stamp</i></p>
Company Details JBS&G Australia Pty Ltd	
I hereby certify that I have undertaken the assessment of the above site and determined the Bushfire Attack Level stated above in accordance with the requirements of AS 3959-2018.	

Reliance on the assessment and determination of the Bushfire Attack Level contained in this certificate should not extend beyond a period of 12 months from the date of issue of the certificate. If this certificate was issued more than 12 months ago, it is recommended that the validity of the determination be confirmed with the Accredited Practitioner and where required an updated certificate issued.

Bushfire Attack Level (BAL) Certificate

Determined in accordance with AS 3959-2018

This Certificate has been issued by a person accredited by Fire Protection Association Australia under the Bushfire Planning and Design (BPAD) Accreditation Scheme. The certificate details the conclusions of the full Bushfire Attack Level Assessment Report (full report) prepared by the Accredited Practitioner.


Property Details and Description of Works

Address Details	Unit no	Street no	Lot no	Street name / Plan Reference	
			722	Bonfire Chase	
Local government area	Suburb			State	Postcode
	Eglinton			WA	6034
Main BCA class of the building	Class 1a	Use(s) of the building	Residential dwelling		
Description of the building or works	Construction of a single Class 1a building and associated Class 10a building/s				

Determination of Highest Bushfire Attack Level

AS 3959 Assessment Procedure	Vegetation Classification	Effective Slope	Separation Distance	BAL
Method 1	Excludable – Clause 2.2.3.2(f)	N/A	N/A	BAL – LOW

BPAD Accredited Practitioner Details

Name Zac Cockerill	<div style="border: 1px solid black; padding: 5px;"> <p>I hereby declare that I am a BPAD accredited bushfire practitioner. </p> <p>Accreditation No. <u>37803</u></p> <p>Signature <u><i>Zac Cockerill</i></u></p> <p>Date <u>015/12/23</u></p> </div>
Company Details JBS&G Australia Pty Ltd	
I hereby certify that I have undertaken the assessment of the above site and determined the Bushfire Attack Level stated above in accordance with the requirements of AS 3959-2018.	

Authorised Practitioner Stamp

Reliance on the assessment and determination of the Bushfire Attack Level contained in this certificate should not extend beyond a period of 12 months from the date of issue of the certificate. If this certificate was issued more than 12 months ago, it is recommended that the validity of the determination be confirmed with the Accredited Practitioner and where required an updated certificate issued.

Bushfire Attack Level (BAL) Certificate

Determined in accordance with AS 3959-2018

This Certificate has been issued by a person accredited by Fire Protection Association Australia under the Bushfire Planning and Design (BPAD) Accreditation Scheme. The certificate details the conclusions of the full Bushfire Attack Level Assessment Report (full report) prepared by the Accredited Practitioner.


Property Details and Description of Works

Address Details	Unit no	Street no	Lot no	Street name / Plan Reference	
			723	Bonfire Chase	
Local government area	Suburb			State	Postcode
	Eglinton			WA	6034
Main BCA class of the building	Use(s) of the building				
Description of the building or works	Class 1a		Residential dwelling		
Construction of a single Class 1a building and associated Class 10a building/s					

Determination of Highest Bushfire Attack Level

AS 3959 Assessment Procedure	Vegetation Classification	Effective Slope	Separation Distance	BAL
Method 1	Excludable – Clause 2.2.3.2(f)	N/A	N/A	BAL – LOW

BPAD Accredited Practitioner Details

Name Zac Cockerill	<div style="border: 1px solid black; padding: 5px;"> <p>I hereby declare that I am a BPAD accredited bushfire practitioner. </p> <p>Accreditation No. <u>37863</u></p> <p>Signature <u>[Signature]</u></p> <p>Date <u>15/12/23</u></p> </div>
Company Details JBS&G Australia Pty Ltd	
I hereby certify that I have undertaken the assessment of the above site and determined the Bushfire Attack Level stated above in accordance with the requirements of AS 3959-2018.	

Authorised Practitioner Stamp

Reliance on the assessment and determination of the Bushfire Attack Level contained in this certificate should not extend beyond a period of 12 months from the date of issue of the certificate. If this certificate was issued more than 12 months ago, it is recommended that the validity of the determination be confirmed with the Accredited Practitioner and where required an updated certificate issued.

Bushfire Attack Level (BAL) Certificate

Determined in accordance with AS 3959-2018

This Certificate has been issued by a person accredited by Fire Protection Association Australia under the Bushfire Planning and Design (BPAD) Accreditation Scheme. The certificate details the conclusions of the full Bushfire Attack Level Assessment Report (full report) prepared by the Accredited Practitioner.


Property Details and Description of Works

Address Details	Unit no	Street no	Lot no	Street name / Plan Reference	
			724	Bonfire Chase	
Local government area	Suburb			State	Postcode
	Eglinton			WA	6034
Main BCA class of the building	Class 1a	Use(s) of the building	Residential dwelling		
Description of the building or works	Construction of a single Class 1a building and associated Class 10a building/s				

Determination of Highest Bushfire Attack Level

AS 3959 Assessment Procedure	Vegetation Classification	Effective Slope	Separation Distance	BAL
Method 1	Excludable – Clause 2.2.3.2(f)	N/A	N/A	BAL – LOW

BPAD Accredited Practitioner Details

Name Zac Cockerill	<div style="border: 1px solid black; padding: 5px;"> <p>I hereby declare that I am a BPAD accredited bushfire practitioner. </p> <p>Accreditation No. <u>37803</u></p> <p>Signature <u>[Signature]</u></p> <p>Date <u>15/12/23</u></p> </div>
Company Details JBS&G Australia Pty Ltd	
I hereby certify that I have undertaken the assessment of the above site and determined the Bushfire Attack Level stated above in accordance with the requirements of AS 3959-2018.	

Authorised Practitioner Stamp

Reliance on the assessment and determination of the Bushfire Attack Level contained in this certificate should not extend beyond a period of 12 months from the date of issue of the certificate. If this certificate was issued more than 12 months ago, it is recommended that the validity of the determination be confirmed with the Accredited Practitioner and where required an updated certificate issued.

Bushfire Attack Level (BAL) Certificate

Determined in accordance with AS 3959-2018

This Certificate has been issued by a person accredited by Fire Protection Association Australia under the Bushfire Planning and Design (BPAD) Accreditation Scheme. The certificate details the conclusions of the full Bushfire Attack Level Assessment Report (full report) prepared by the Accredited Practitioner.


Property Details and Description of Works

Address Details	Unit no	Street no	Lot no	Street name / Plan Reference	
			725	Bonfire Chase	
Local government area	Suburb			State	Postcode
	Eglinton			WA	6034
Main BCA class of the building	Class 1a	Use(s) of the building	Residential dwelling		
Description of the building or works	Construction of a single Class 1a building and associated Class 10a building/s				

Determination of Highest Bushfire Attack Level

AS 3959 Assessment Procedure	Vegetation Classification	Effective Slope	Separation Distance	BAL
Method 1	Excludable – Clause 2.2.3.2(f)	N/A	N/A	BAL – LOW

BPAD Accredited Practitioner Details

Name Zac Cockerill	<div style="border: 1px solid black; padding: 5px;"> <p>I hereby declare that I am a BPAD accredited bushfire practitioner. </p> <p>Accreditation No. <u>37803</u></p> <p>Signature <u>[Signature]</u></p> <p>Date <u>15/12/23</u></p> </div> <p><i>Authorised Practitioner Stamp</i></p>
Company Details JBS&G Australia Pty Ltd	
I hereby certify that I have undertaken the assessment of the above site and determined the Bushfire Attack Level stated above in accordance with the requirements of AS 3959-2018.	

Reliance on the assessment and determination of the Bushfire Attack Level contained in this certificate should not extend beyond a period of 12 months from the date of issue of the certificate. If this certificate was issued more than 12 months ago, it is recommended that the validity of the determination be confirmed with the Accredited Practitioner and where required an updated certificate issued.

Bushfire Attack Level (BAL) Certificate

Determined in accordance with AS 3959-2018

This Certificate has been issued by a person accredited by Fire Protection Association Australia under the Bushfire Planning and Design (BPAD) Accreditation Scheme. The certificate details the conclusions of the full Bushfire Attack Level Assessment Report (full report) prepared by the Accredited Practitioner.


Property Details and Description of Works

Address Details	Unit no	Street no	Lot no	Street name / Plan Reference	
			726	Bonfire Chase	
Local government area	Suburb			State	Postcode
	Eglinton			WA	6034
Main BCA class of the building	Class 1a	Use(s) of the building	Residential dwelling		
Description of the building or works	Construction of a single Class 1a building and associated Class 10a building/s				

Determination of Highest Bushfire Attack Level

AS 3959 Assessment Procedure	Vegetation Classification	Effective Slope	Separation Distance	BAL
Method 1	Excludable – Clause 2.2.3.2(f)	N/A	N/A	BAL – LOW

BPAD Accredited Practitioner Details

Name Zac Cockerill	<div style="border: 1px solid black; padding: 5px;"> <p>I hereby declare that I am a BPAD accredited bushfire practitioner. </p> <p>Accreditation No. <u>37803</u></p> <p>Signature <u>[Signature]</u></p> <p>Date <u>15/12/23</u></p> </div>
Company Details JBS&G Australia Pty Ltd	
I hereby certify that I have undertaken the assessment of the above site and determined the Bushfire Attack Level stated above in accordance with the requirements of AS 3959-2018.	

Authorised Practitioner Stamp

Reliance on the assessment and determination of the Bushfire Attack Level contained in this certificate should not extend beyond a period of 12 months from the date of issue of the certificate. If this certificate was issued more than 12 months ago, it is recommended that the validity of the determination be confirmed with the Accredited Practitioner and where required an updated certificate issued.

Bushfire Attack Level (BAL) Certificate

Determined in accordance with AS 3959-2018

This Certificate has been issued by a person accredited by Fire Protection Association Australia under the Bushfire Planning and Design (BPAD) Accreditation Scheme. The certificate details the conclusions of the full Bushfire Attack Level Assessment Report (full report) prepared by the Accredited Practitioner.


Property Details and Description of Works

Address Details	Unit no	Street no	Lot no	Street name / Plan Reference	
			727	Bonfire Chase	
Local government area	Suburb			State	Postcode
	Eglinton			WA	6034
Main BCA class of the building	Class 1a	Use(s) of the building	Residential dwelling		
Description of the building or works	Construction of a single Class 1a building and associated Class 10a building/s				

Determination of Highest Bushfire Attack Level

AS 3959 Assessment Procedure	Vegetation Classification	Effective Slope	Separation Distance	BAL
Method 1	Excludable – Clause 2.2.3.2(f)	N/A	N/A	BAL – LOW

BPAD Accredited Practitioner Details

Name Zac Cockerill	<div style="border: 1px solid black; padding: 5px;"> <p>I hereby declare that I am a BPAD accredited bushfire practitioner. </p> <p>Accreditation No. <u>37803</u></p> <p>Signature <u>ZC</u></p> <p>Date <u>15/12/23</u></p> </div> <p><i>Authorised Practitioner Stamp</i></p>
Company Details JBS&G Australia Pty Ltd	
I hereby certify that I have undertaken the assessment of the above site and determined the Bushfire Attack Level stated above in accordance with the requirements of AS 3959-2018.	

Reliance on the assessment and determination of the Bushfire Attack Level contained in this certificate should not extend beyond a period of 12 months from the date of issue of the certificate. If this certificate was issued more than 12 months ago, it is recommended that the validity of the determination be confirmed with the Accredited Practitioner and where required an updated certificate issued.

Bushfire Attack Level (BAL) Certificate

Determined in accordance with AS 3959-2018

This Certificate has been issued by a person accredited by Fire Protection Association Australia under the Bushfire Planning and Design (BPAD) Accreditation Scheme. The certificate details the conclusions of the full Bushfire Attack Level Assessment Report (full report) prepared by the Accredited Practitioner.


Property Details and Description of Works

Address Details	Unit no	Street no	Lot no	Street name / Plan Reference	
			728	Bonfire Chase	
Local government area	Suburb			State	Postcode
	Eglinton			WA	6034
Main BCA class of the building	Class 1a	Use(s) of the building	Residential dwelling		
Description of the building or works	Construction of a single Class 1a building and associated Class 10a building/s				

Determination of Highest Bushfire Attack Level

AS 3959 Assessment Procedure	Vegetation Classification	Effective Slope	Separation Distance	BAL
Method 1	Excludable – Clause 2.2.3.2(f)	N/A	N/A	BAL – LOW

BPAD Accredited Practitioner Details

Name Zac Cockerill	<div style="border: 1px solid black; padding: 5px;"> <p>I hereby declare that I am a BPAD accredited bushfire practitioner. </p> <p>Accreditation No. <u>37803</u></p> <p>Signature <u>[Signature]</u></p> <p>Date <u>15/12/23</u></p> </div>
Company Details JBS&G Australia Pty Ltd	
I hereby certify that I have undertaken the assessment of the above site and determined the Bushfire Attack Level stated above in accordance with the requirements of AS 3959-2018.	

Authorised Practitioner Stamp

Reliance on the assessment and determination of the Bushfire Attack Level contained in this certificate should not extend beyond a period of 12 months from the date of issue of the certificate. If this certificate was issued more than 12 months ago, it is recommended that the validity of the determination be confirmed with the Accredited Practitioner and where required an updated certificate issued.

Bushfire Attack Level (BAL) Certificate

Determined in accordance with AS 3959-2018

This Certificate has been issued by a person accredited by Fire Protection Association Australia under the Bushfire Planning and Design (BPAD) Accreditation Scheme. The certificate details the conclusions of the full Bushfire Attack Level Assessment Report (full report) prepared by the Accredited Practitioner.


Property Details and Description of Works

Address Details	Unit no	Street no	Lot no	Street name / Plan Reference	
			729	Bonfire Chase	
Local government area	Suburb			State	Postcode
	Eglinton			WA	6034
Main BCA class of the building	Use(s) of the building				
Class 1a	Residential dwelling				
Description of the building or works	Construction of a single Class 1a building and associated Class 10a building/s				

Determination of Highest Bushfire Attack Level

AS 3959 Assessment Procedure	Vegetation Classification	Effective Slope	Separation Distance	BAL
Method 1	Excludable – Clause 2.2.3.2(f)	N/A	N/A	BAL – LOW

BPAD Accredited Practitioner Details

Name Zac Cockerill	 <p>I hereby declare that I am a BPAD accredited bushfire practitioner.</p> <p>Accreditation No. 37803</p> <p>Signature <i>ZC</i></p> <p>Date 15/12/23</p>
Company Details JBS&G Australia Pty Ltd	
I hereby certify that I have undertaken the assessment of the above site and determined the Bushfire Attack Level stated above in accordance with the requirements of AS 3959-2018.	

Authorised Practitioner Stamp

Reliance on the assessment and determination of the Bushfire Attack Level contained in this certificate should not extend beyond a period of 12 months from the date of issue of the certificate. If this certificate was issued more than 12 months ago, it is recommended that the validity of the determination be confirmed with the Accredited Practitioner and where required an updated certificate issued.

Bushfire Attack Level (BAL) Certificate

Determined in accordance with AS 3959-2018

This Certificate has been issued by a person accredited by Fire Protection Association Australia under the Bushfire Planning and Design (BPAD) Accreditation Scheme. The certificate details the conclusions of the full Bushfire Attack Level Assessment Report (full report) prepared by the Accredited Practitioner.


Property Details and Description of Works

Address Details	Unit no	Street no	Lot no	Street name / Plan Reference	
			742	Flicker Way	
Local government area	Suburb			State	Postcode
	Eglinton			WA	6034
Main BCA class of the building	Class 1a	Use(s) of the building	Residential dwelling		
Description of the building or works	Construction of a single Class 1a building and associated Class 10a building/s				

Determination of Highest Bushfire Attack Level

AS 3959 Assessment Procedure	Vegetation Classification	Effective Slope	Separation Distance	BAL
Method 1	Excludable – Clause 2.2.3.2(f)	N/A	N/A	BAL – LOW

BPAD Accredited Practitioner Details

Name Zac Cockerill	<div style="border: 1px solid black; padding: 5px;"> <p>I hereby declare that I am a BPAD accredited bushfire practitioner. </p> <p>Accreditation No. <u>37803</u></p> <p>Signature <u>[Signature]</u></p> <p>Date <u>15/12/23</u></p> </div>
Company Details JBS&G Australia Pty Ltd	
I hereby certify that I have undertaken the assessment of the above site and determined the Bushfire Attack Level stated above in accordance with the requirements of AS 3959-2018.	

Authorised Practitioner Stamp

Reliance on the assessment and determination of the Bushfire Attack Level contained in this certificate should not extend beyond a period of 12 months from the date of issue of the certificate. If this certificate was issued more than 12 months ago, it is recommended that the validity of the determination be confirmed with the Accredited Practitioner and where required an updated certificate issued.

Bushfire Attack Level (BAL) Certificate

Determined in accordance with AS 3959-2018

This Certificate has been issued by a person accredited by Fire Protection Association Australia under the Bushfire Planning and Design (BPAD) Accreditation Scheme. The certificate details the conclusions of the full Bushfire Attack Level Assessment Report (full report) prepared by the Accredited Practitioner.


Property Details and Description of Works

Address Details	Unit no	Street no	Lot no	Street name / Plan Reference	
			743	Flicker Way	
Local government area	Suburb			State	Postcode
	Eglinton			WA	6034
Main BCA class of the building	Class 1a	Use(s) of the building	Residential dwelling		
Description of the building or works	Construction of a single Class 1a building and associated Class 10a building/s				

Determination of Highest Bushfire Attack Level

AS 3959 Assessment Procedure	Vegetation Classification	Effective Slope	Separation Distance	BAL
Method 1	Excludable – Clause 2.2.3.2(f)	N/A	N/A	BAL – LOW

BPAD Accredited Practitioner Details

Name Zac Cockerill	<div style="border: 1px solid black; padding: 5px;"> <p>I hereby declare that I am a BPAD accredited bushfire practitioner. </p> <p>Accreditation No. <u>37803</u></p> <p>Signature <u>[Signature]</u></p> <p>Date <u>15/12/23</u></p> </div> <p><i>Authorised Practitioner Stamp</i></p>
Company Details JBS&G Australia Pty Ltd	
I hereby certify that I have undertaken the assessment of the above site and determined the Bushfire Attack Level stated above in accordance with the requirements of AS 3959-2018.	

Reliance on the assessment and determination of the Bushfire Attack Level contained in this certificate should not extend beyond a period of 12 months from the date of issue of the certificate. If this certificate was issued more than 12 months ago, it is recommended that the validity of the determination be confirmed with the Accredited Practitioner and where required an updated certificate issued.

Bushfire Attack Level (BAL) Certificate

Determined in accordance with AS 3959-2018

This Certificate has been issued by a person accredited by Fire Protection Association Australia under the Bushfire Planning and Design (BPAD) Accreditation Scheme. The certificate details the conclusions of the full Bushfire Attack Level Assessment Report (full report) prepared by the Accredited Practitioner.


Property Details and Description of Works

Address Details	Unit no	Street no	Lot no 744	Street name / Plan Reference Bonfire Chase	
	Suburb Eglinton			State WA	Postcode 6034
Local government area	City of Wanneroo				
Main BCA class of the building	Class 1a	Use(s) of the building	Residential dwelling		
Description of the building or works	Construction of a single Class 1a building and associated Class 10a building/s				

Determination of Highest Bushfire Attack Level

AS 3959 Assessment Procedure	Vegetation Classification	Effective Slope	Separation Distance	BAL
Method 1	Excludable – Clause 2.2.3.2(f)	N/A	N/A	BAL – LOW

BPAD Accredited Practitioner Details

Name Zac Cockerill	<div style="border: 1px solid black; padding: 5px;"> <p>I hereby declare that I am a BPAD accredited bushfire practitioner. </p> <p>Accreditation No. <u>37803</u></p> <p>Signature <u><i>Zac Cockerill</i></u></p> <p>Date <u>15/12/23</u></p> </div>
Company Details JBS&G Australia Pty Ltd	
I hereby certify that I have undertaken the assessment of the above site and determined the Bushfire Attack Level stated above in accordance with the requirements of AS 3959-2018.	

Authorised Practitioner Stamp

Reliance on the assessment and determination of the Bushfire Attack Level contained in this certificate should not extend beyond a period of 12 months from the date of issue of the certificate. If this certificate was issued more than 12 months ago, it is recommended that the validity of the determination be confirmed with the Accredited Practitioner and where required an updated certificate issued.

Bushfire Attack Level (BAL) Certificate

Determined in accordance with AS 3959-2018

This Certificate has been issued by a person accredited by Fire Protection Association Australia under the Bushfire Planning and Design (BPAD) Accreditation Scheme. The certificate details the conclusions of the full Bushfire Attack Level Assessment Report (full report) prepared by the Accredited Practitioner.


Property Details and Description of Works

Address Details	Unit no	Street no	Lot no	Street name / Plan Reference	
			745	Bonfire Chase	
Local government area	Suburb			State	Postcode
	Eglinton			WA	6034
Main BCA class of the building	Class 1a	Use(s) of the building	Residential dwelling		
Description of the building or works	Construction of a single Class 1a building and associated Class 10a building/s				

Determination of Highest Bushfire Attack Level

AS 3959 Assessment Procedure	Vegetation Classification	Effective Slope	Separation Distance	BAL
Method 1	Excludable – Clause 2.2.3.2(f)	N/A	N/A	BAL – LOW

BPAD Accredited Practitioner Details

Name Zac Cockerill	<div style="border: 1px solid black; padding: 5px;"> <p>I hereby declare that I am a BPAD accredited bushfire practitioner. </p> <p>Accreditation No. <u>37803</u></p> <p>Signature <u><i>Zac Cockerill</i></u></p> <p>Date <u>15/12/23</u></p> </div>
Company Details JBS&G Australia Pty Ltd	
I hereby certify that I have undertaken the assessment of the above site and determined the Bushfire Attack Level stated above in accordance with the requirements of AS 3959-2018.	

Authorised Practitioner Stamp

Reliance on the assessment and determination of the Bushfire Attack Level contained in this certificate should not extend beyond a period of 12 months from the date of issue of the certificate. If this certificate was issued more than 12 months ago, it is recommended that the validity of the determination be confirmed with the Accredited Practitioner and where required an updated certificate issued.

Bushfire Attack Level (BAL) Certificate

Determined in accordance with AS 3959-2018

This Certificate has been issued by a person accredited by Fire Protection Association Australia under the Bushfire Planning and Design (BPAD) Accreditation Scheme. The certificate details the conclusions of the full Bushfire Attack Level Assessment Report (full report) prepared by the Accredited Practitioner.


Property Details and Description of Works

Address Details	Unit no	Street no	Lot no	Street name / Plan Reference	
			746	Bonfire Chase	
Local government area	Suburb			State	Postcode
	Eglinton			WA	6034
Main BCA class of the building	Class 1a	Use(s) of the building	Residential dwelling		
Description of the building or works	Construction of a single Class 1a building and associated Class 10a building/s				

Determination of Highest Bushfire Attack Level

AS 3959 Assessment Procedure	Vegetation Classification	Effective Slope	Separation Distance	BAL
Method 1	Excludable – Clause 2.2.3.2(f)	N/A	N/A	BAL – LOW

BPAD Accredited Practitioner Details

Name Zac Cockerill	<div style="border: 1px solid black; padding: 5px;"> <p>I hereby declare that I am a BPAD accredited bushfire practitioner. </p> <p>Accreditation No. <u>37803</u></p> <p>Signature <u>[Signature]</u></p> <p>Date <u>15/12/23</u></p> </div> <p><i>Authorised Practitioner Stamp</i></p>
Company Details JBS&G Australia Pty Ltd	
I hereby certify that I have undertaken the assessment of the above site and determined the Bushfire Attack Level stated above in accordance with the requirements of AS 3959-2018.	

Reliance on the assessment and determination of the Bushfire Attack Level contained in this certificate should not extend beyond a period of 12 months from the date of issue of the certificate. If this certificate was issued more than 12 months ago, it is recommended that the validity of the determination be confirmed with the Accredited Practitioner and where required an updated certificate issued.

Bushfire Attack Level (BAL) Certificate

Determined in accordance with AS 3959-2018

This Certificate has been issued by a person accredited by Fire Protection Association Australia under the Bushfire Planning and Design (BPAD) Accreditation Scheme. The certificate details the conclusions of the full Bushfire Attack Level Assessment Report (full report) prepared by the Accredited Practitioner.


Property Details and Description of Works

Address Details	Unit no	Street no	Lot no	Street name / Plan Reference	
			747	Bonfire Chase	
Local government area	Suburb			State	Postcode
	Eglinton			WA	6034
Main BCA class of the building	Class 1a	Use(s) of the building	Residential dwelling		
Description of the building or works	Construction of a single Class 1a building and associated Class 10a building/s				

Determination of Highest Bushfire Attack Level

AS 3959 Assessment Procedure	Vegetation Classification	Effective Slope	Separation Distance	BAL
Method 1	Excludable – Clause 2.2.3.2(f)	N/A	N/A	BAL – LOW

BPAD Accredited Practitioner Details

Name Zac Cockerill	<div style="border: 1px solid black; padding: 5px;"> <p>I hereby declare that I am a BPAD accredited bushfire practitioner. </p> <p>Accreditation No. <u>37803</u></p> <p>Signature <u>[Signature]</u></p> <p>Date <u>15/12/23</u></p> </div> <p><i>Authorised Practitioner Stamp</i></p>
Company Details JBS&G Australia Pty Ltd	
I hereby certify that I have undertaken the assessment of the above site and determined the Bushfire Attack Level stated above in accordance with the requirements of AS 3959-2018.	

Reliance on the assessment and determination of the Bushfire Attack Level contained in this certificate should not extend beyond a period of 12 months from the date of issue of the certificate. If this certificate was issued more than 12 months ago, it is recommended that the validity of the determination be confirmed with the Accredited Practitioner and where required an updated certificate issued.

Bushfire Attack Level (BAL) Certificate

Determined in accordance with AS 3959-2018

This Certificate has been issued by a person accredited by Fire Protection Association Australia under the Bushfire Planning and Design (BPAD) Accreditation Scheme. The certificate details the conclusions of the full Bushfire Attack Level Assessment Report (full report) prepared by the Accredited Practitioner.


Property Details and Description of Works

Address Details	Unit no	Street no	Lot no 748	Street name / Plan Reference Bonfire Chase		
	Suburb Eglinton			State WA	Postcode 6034	
Local government area	City of Wanneroo					
Main BCA class of the building	Class 1a	Use(s) of the building	Residential dwelling			
Description of the building or works	Construction of a single Class 1a building and associated Class 10a building/s					

Determination of Highest Bushfire Attack Level

AS 3959 Assessment Procedure	Vegetation Classification	Effective Slope	Separation Distance	BAL
Method 1	Excludable – Clause 2.2.3.2(f)	N/A	N/A	BAL – LOW

BPAD Accredited Practitioner Details

Name Zac Cockerill	 <p>I hereby declare that I am a BPAD accredited bushfire practitioner.</p> <p>Accreditation No. 37803</p> <p>Signature <i>[Signature]</i></p> <p>Date 15/12/23</p>
Company Details JBS&G Australia Pty Ltd	
I hereby certify that I have undertaken the assessment of the above site and determined the Bushfire Attack Level stated above in accordance with the requirements of AS 3959-2018.	

Authorised Practitioner Stamp

Reliance on the assessment and determination of the Bushfire Attack Level contained in this certificate should not extend beyond a period of 12 months from the date of issue of the certificate. If this certificate was issued more than 12 months ago, it is recommended that the validity of the determination be confirmed with the Accredited Practitioner and where required an updated certificate issued.

Bushfire Attack Level (BAL) Certificate

Determined in accordance with AS 3959-2018

This Certificate has been issued by a person accredited by Fire Protection Association Australia under the Bushfire Planning and Design (BPAD) Accreditation Scheme. The certificate details the conclusions of the full Bushfire Attack Level Assessment Report (full report) prepared by the Accredited Practitioner.


Property Details and Description of Works

Address Details	Unit no	Street no	Lot no	Street name / Plan Reference	
			749	Bonfire Chase	
Local government area	Suburb			State	Postcode
	Eglinton			WA	6034
Main BCA class of the building	Class 1a	Use(s) of the building	Residential dwelling		
Description of the building or works	Construction of a single Class 1a building and associated Class 10a building/s				

Determination of Highest Bushfire Attack Level

AS 3959 Assessment Procedure	Vegetation Classification	Effective Slope	Separation Distance	BAL
Method 1	Excludable – Clause 2.2.3.2(f)	N/A	N/A	BAL – LOW

BPAD Accredited Practitioner Details

Name Zac Cockerill	 <p><i>Authorised Practitioner Stamp</i></p>
Company Details JBS&G Australia Pty Ltd	
I hereby certify that I have undertaken the assessment of the above site and determined the Bushfire Attack Level stated above in accordance with the requirements of AS 3959-2018.	

Reliance on the assessment and determination of the Bushfire Attack Level contained in this certificate should not extend beyond a period of 12 months from the date of issue of the certificate. If this certificate was issued more than 12 months ago, it is recommended that the validity of the determination be confirmed with the Accredited Practitioner and where required an updated certificate issued.

Bushfire Attack Level (BAL) Certificate

Determined in accordance with AS 3959-2018

This Certificate has been issued by a person accredited by Fire Protection Association Australia under the Bushfire Planning and Design (BPAD) Accreditation Scheme. The certificate details the conclusions of the full Bushfire Attack Level Assessment Report (full report) prepared by the Accredited Practitioner.


Property Details and Description of Works

Address Details	Unit no	Street no	Lot no	Street name / Plan Reference	
			1169	Impressions Drive	
Local government area	Suburb			State	Postcode
	Eglinton			WA	6034
Main BCA class of the building	Use(s) of the building				
Class 1a	Residential dwelling				
Description of the building or works	Construction of a single Class 1a building and associated Class 10a building/s				

Determination of Highest Bushfire Attack Level

AS 3959 Assessment Procedure	Vegetation Classification	Effective Slope	Separation Distance	BAL
Method 1	Excludable – Clause 2.2.3.2(f)	N/A	N/A	BAL – LOW

BPAD Accredited Practitioner Details

Name Zac Cockerill	 <p>I hereby declare that I am a BPAD accredited bushfire practitioner.</p> <p>Accreditation No. 37803</p> <p>Signature <i>ZC</i></p> <p>Date 15/12/23</p>
Company Details JBS&G Australia Pty Ltd	
I hereby certify that I have undertaken the assessment of the above site and determined the Bushfire Attack Level stated above in accordance with the requirements of AS 3959-2018.	

Authorised Practitioner Stamp

Reliance on the assessment and determination of the Bushfire Attack Level contained in this certificate should not extend beyond a period of 12 months from the date of issue of the certificate. If this certificate was issued more than 12 months ago, it is recommended that the validity of the determination be confirmed with the Accredited Practitioner and where required an updated certificate issued.

Bushfire Attack Level (BAL) Certificate

Determined in accordance with AS 3959-2018

This Certificate has been issued by a person accredited by Fire Protection Association Australia under the Bushfire Planning and Design (BPAD) Accreditation Scheme. The certificate details the conclusions of the full Bushfire Attack Level Assessment Report (full report) prepared by the Accredited Practitioner.


Property Details and Description of Works

Address Details	Unit no	Street no	Lot no	Street name / Plan Reference	
			1170	Impressions Drive	
Local government area	Suburb			State	Postcode
	Eglinton			WA	6034
Main BCA class of the building	Class 1a	Use(s) of the building	Residential dwelling		
Description of the building or works	Construction of a single Class 1a building and associated Class 10a building/s				

Determination of Highest Bushfire Attack Level

AS 3959 Assessment Procedure	Vegetation Classification	Effective Slope	Separation Distance	BAL
Method 1	Excludable – Clause 2.2.3.2(f)	N/A	N/A	BAL – LOW

BPAD Accredited Practitioner Details

Name Zac Cockerill	<div style="border: 1px solid black; padding: 5px;"> <p>I hereby declare that I am a BPAD accredited bushfire practitioner. </p> <p>Accreditation No. <u>37803</u></p> <p>Signature <u>[Signature]</u></p> <p>Date <u>15/12/23</u></p> </div> <p><i>Authorised Practitioner Stamp</i></p>
Company Details JBS&G Australia Pty Ltd	
I hereby certify that I have undertaken the assessment of the above site and determined the Bushfire Attack Level stated above in accordance with the requirements of AS 3959-2018.	

Reliance on the assessment and determination of the Bushfire Attack Level contained in this certificate should not extend beyond a period of 12 months from the date of issue of the certificate. If this certificate was issued more than 12 months ago, it is recommended that the validity of the determination be confirmed with the Accredited Practitioner and where required an updated certificate issued.

Bushfire Attack Level (BAL) Certificate

Determined in accordance with AS 3959-2018

This Certificate has been issued by a person accredited by Fire Protection Association Australia under the Bushfire Planning and Design (BPAD) Accreditation Scheme. The certificate details the conclusions of the full Bushfire Attack Level Assessment Report (full report) prepared by the Accredited Practitioner.


Property Details and Description of Works

Address Details	Unit no	Street no	Lot no	Street name / Plan Reference	
			1171	Flicker Way	
Local government area	Suburb		State	Postcode	
	Eglinton		WA	6034	
Main BCA class of the building	Class 1a	Use(s) of the building	Residential dwelling		
Description of the building or works	Construction of a single Class 1a building and associated Class 10a building/s				

Determination of Highest Bushfire Attack Level

AS 3959 Assessment Procedure	Vegetation Classification	Effective Slope	Separation Distance	BAL
Method 1	Excludable – Clause 2.2.3.2(f)	N/A	N/A	BAL – LOW

BPAD Accredited Practitioner Details

Name Zac Cockerill	<div style="border: 1px solid black; padding: 5px;"> <p>I hereby declare that I am a BPAD accredited bushfire practitioner. </p> <p>Accreditation No. <u>37803</u></p> <p>Signature <u>[Signature]</u></p> <p>Date <u>15/12/23</u></p> </div> <p><i>Authorised Practitioner Stamp</i></p>
Company Details JBS&G Australia Pty Ltd	
I hereby certify that I have undertaken the assessment of the above site and determined the Bushfire Attack Level stated above in accordance with the requirements of AS 3959-2018.	

Reliance on the assessment and determination of the Bushfire Attack Level contained in this certificate should not extend beyond a period of 12 months from the date of issue of the certificate. If this certificate was issued more than 12 months ago, it is recommended that the validity of the determination be confirmed with the Accredited Practitioner and where required an updated certificate issued.

Bushfire Attack Level (BAL) Certificate

Determined in accordance with AS 3959-2018

This Certificate has been issued by a person accredited by Fire Protection Association Australia under the Bushfire Planning and Design (BPAD) Accreditation Scheme. The certificate details the conclusions of the full Bushfire Attack Level Assessment Report (full report) prepared by the Accredited Practitioner.


Property Details and Description of Works

Address Details	Unit no	Street no	Lot no	Street name / Plan Reference	
			1172	Flicker Way	
Local government area	Suburb			State	Postcode
	Eglinton			WA	6034
Main BCA class of the building	Class 1a	Use(s) of the building	Residential dwelling		
Description of the building or works	Construction of a single Class 1a building and associated Class 10a building/s				

Determination of Highest Bushfire Attack Level

AS 3959 Assessment Procedure	Vegetation Classification	Effective Slope	Separation Distance	BAL
Method 1	Excludable – Clause 2.2.3.2(f)	N/A	N/A	BAL – LOW

BPAD Accredited Practitioner Details

Name Zac Cockerill	<div style="border: 1px solid black; padding: 5px;"> <p>I hereby declare that I am a BPAD accredited bushfire practitioner. </p> <p>Accreditation No. <u>37803</u></p> <p>Signature <u><i>ZC</i></u></p> <p>Date <u>15/12/23</u></p> </div>
Company Details JBS&G Australia Pty Ltd	
I hereby certify that I have undertaken the assessment of the above site and determined the Bushfire Attack Level stated above in accordance with the requirements of AS 3959-2018.	

Authorised Practitioner Stamp

Reliance on the assessment and determination of the Bushfire Attack Level contained in this certificate should not extend beyond a period of 12 months from the date of issue of the certificate. If this certificate was issued more than 12 months ago, it is recommended that the validity of the determination be confirmed with the Accredited Practitioner and where required an updated certificate issued.

Bushfire Attack Level (BAL) Certificate

Determined in accordance with AS 3959-2018

This Certificate has been issued by a person accredited by Fire Protection Association Australia under the Bushfire Planning and Design (BPAD) Accreditation Scheme. The certificate details the conclusions of the full Bushfire Attack Level Assessment Report (full report) prepared by the Accredited Practitioner.


Property Details and Description of Works

Address Details	Unit no	Street no	Lot no 1173	Street name / Plan Reference Flicker Way	
	Suburb Eglinton			State WA	Postcode 6034
Local government area	City of Wanneroo				
Main BCA class of the building	Class 1a	Use(s) of the building	Residential dwelling		
Description of the building or works	Construction of a single Class 1a building and associated Class 10a building/s				

Determination of Highest Bushfire Attack Level

AS 3959 Assessment Procedure	Vegetation Classification	Effective Slope	Separation Distance	BAL
Method 1	Excludable – Clause 2.2.3.2(f)	N/A	N/A	BAL – LOW

BPAD Accredited Practitioner Details

Name Zac Cockerill	 <p>I hereby declare that I am a BPAD accredited bushfire practitioner.</p> <p>Accreditation No. 37803</p> <p>Signature <i>ZC</i></p> <p>Date 15/12/23</p>
Company Details JBS&G Australia Pty Ltd	
I hereby certify that I have undertaken the assessment of the above site and determined the Bushfire Attack Level stated above in accordance with the requirements of AS 3959-2018.	

Authorised Practitioner Stamp

Reliance on the assessment and determination of the Bushfire Attack Level contained in this certificate should not extend beyond a period of 12 months from the date of issue of the certificate. If this certificate was issued more than 12 months ago, it is recommended that the validity of the determination be confirmed with the Accredited Practitioner and where required an updated certificate issued.

Bushfire Attack Level (BAL) Certificate

Determined in accordance with AS 3959-2018

This Certificate has been issued by a person accredited by Fire Protection Association Australia under the Bushfire Planning and Design (BPAD) Accreditation Scheme. The certificate details the conclusions of the full Bushfire Attack Level Assessment Report (full report) prepared by the Accredited Practitioner.


Property Details and Description of Works

Address Details	Unit no	Street no	Lot no 1174	Street name / Plan Reference Flicker Way		
	Suburb Eglinton			State WA	Postcode 6034	
Local government area	City of Wanneroo					
Main BCA class of the building	Class 1a	Use(s) of the building	Residential dwelling			
Description of the building or works	Construction of a single Class 1a building and associated Class 10a building/s					

Determination of Highest Bushfire Attack Level

AS 3959 Assessment Procedure	Vegetation Classification	Effective Slope	Separation Distance	BAL
Method 1	Excludable – Clause 2.2.3.2(f)	N/A	N/A	BAL – LOW

BPAD Accredited Practitioner Details

Name Zac Cockerill	 <p>I hereby declare that I am a BPAD accredited bushfire practitioner.</p> <p>Accreditation No. <u>37803</u></p> <p>Signature <u>[Signature]</u></p> <p>Date <u>15/12/23</u></p>
Company Details JBS&G Australia Pty Ltd	
I hereby certify that I have undertaken the assessment of the above site and determined the Bushfire Attack Level stated above in accordance with the requirements of AS 3959-2018.	

Authorised Practitioner Stamp

Reliance on the assessment and determination of the Bushfire Attack Level contained in this certificate should not extend beyond a period of 12 months from the date of issue of the certificate. If this certificate was issued more than 12 months ago, it is recommended that the validity of the determination be confirmed with the Accredited Practitioner and where required an updated certificate issued.

Bushfire Attack Level (BAL) Certificate

Determined in accordance with AS 3959-2018

This Certificate has been issued by a person accredited by Fire Protection Association Australia under the Bushfire Planning and Design (BPAD) Accreditation Scheme. The certificate details the conclusions of the full Bushfire Attack Level Assessment Report (full report) prepared by the Accredited Practitioner.


Property Details and Description of Works

Address Details	Unit no	Street no	Lot no	Street name / Plan Reference	
			1175	Flicker Way	
Local government area	Suburb			State	Postcode
	Eglinton			WA	6034
Main BCA class of the building	Class 1a	Use(s) of the building	Residential dwelling		
Description of the building or works	Construction of a single Class 1a building and associated Class 10a building/s				

Determination of Highest Bushfire Attack Level

AS 3959 Assessment Procedure	Vegetation Classification	Effective Slope	Separation Distance	BAL
Method 1	Excludable – Clause 2.2.3.2(f)	N/A	N/A	BAL – LOW

BPAD Accredited Practitioner Details

Name Zac Cockerill	<div style="border: 1px solid black; padding: 5px;"> <p>I hereby declare that I am a BPAD accredited bushfire practitioner. </p> <p>Accreditation No. <u>37803</u></p> <p>Signature <u>[Signature]</u></p> <p>Date <u>15/12/23</u></p> </div> <p><i>Authorised Practitioner Stamp</i></p>
Company Details JBS&G Australia Pty Ltd	
I hereby certify that I have undertaken the assessment of the above site and determined the Bushfire Attack Level stated above in accordance with the requirements of AS 3959-2018.	

Reliance on the assessment and determination of the Bushfire Attack Level contained in this certificate should not extend beyond a period of 12 months from the date of issue of the certificate. If this certificate was issued more than 12 months ago, it is recommended that the validity of the determination be confirmed with the Accredited Practitioner and where required an updated certificate issued.

Bushfire Attack Level (BAL) Certificate

Determined in accordance with AS 3959-2018

This Certificate has been issued by a person accredited by Fire Protection Association Australia under the Bushfire Planning and Design (BPAD) Accreditation Scheme. The certificate details the conclusions of the full Bushfire Attack Level Assessment Report (full report) prepared by the Accredited Practitioner.


Property Details and Description of Works

Address Details	Unit no	Street no	Lot no	Street name / Plan Reference	
			1176	Flicker Way	
Local government area	Suburb			State	Postcode
	Eglinton			WA	6034
Main BCA class of the building	Class 1a	Use(s) of the building	Residential dwelling		
Description of the building or works	Construction of a single Class 1a building and associated Class 10a building/s				

Determination of Highest Bushfire Attack Level

AS 3959 Assessment Procedure	Vegetation Classification	Effective Slope	Separation Distance	BAL
Method 1	Excludable – Clause 2.2.3.2(f)	N/A	N/A	BAL – LOW

BPAD Accredited Practitioner Details

Name Zac Cockerill	<div style="border: 1px solid black; padding: 5px;"> <p>I hereby declare that I am a BPAD accredited bushfire practitioner. </p> <p>Accreditation No. <u>37803</u></p> <p>Signature <u><i>ZC</i></u></p> <p>Date <u>15/12/23</u></p> </div>
Company Details JBS&G Australia Pty Ltd	
I hereby certify that I have undertaken the assessment of the above site and determined the Bushfire Attack Level stated above in accordance with the requirements of AS 3959-2018.	

Authorised Practitioner Stamp

Reliance on the assessment and determination of the Bushfire Attack Level contained in this certificate should not extend beyond a period of 12 months from the date of issue of the certificate. If this certificate was issued more than 12 months ago, it is recommended that the validity of the determination be confirmed with the Accredited Practitioner and where required an updated certificate issued.

Bushfire Attack Level (BAL) Certificate

Determined in accordance with AS 3959-2018

This Certificate has been issued by a person accredited by Fire Protection Association Australia under the Bushfire Planning and Design (BPAD) Accreditation Scheme. The certificate details the conclusions of the full Bushfire Attack Level Assessment Report (full report) prepared by the Accredited Practitioner.


Property Details and Description of Works

Address Details	Unit no	Street no	Lot no 1177	Street name / Plan Reference Flicker Way		
	Suburb Eglinton			State WA	Postcode 6034	
Local government area	City of Wanneroo					
Main BCA class of the building	Class 1a	Use(s) of the building	Residential dwelling			
Description of the building or works	Construction of a single Class 1a building and associated Class 10a building/s					

Determination of Highest Bushfire Attack Level

AS 3959 Assessment Procedure	Vegetation Classification	Effective Slope	Separation Distance	BAL
Method 1	Excludable – Clause 2.2.3.2(f)	N/A	N/A	BAL – LOW

BPAD Accredited Practitioner Details

Name Zac Cockerill	<div style="border: 1px solid black; padding: 5px;"> <p>I hereby declare that I am a BPAD accredited bushfire practitioner. </p> <p>Accreditation No. <u>37803</u></p> <p>Signature <u>[Signature]</u></p> <p>Date <u>15/12/23</u></p> </div> <p><i>Authorised Practitioner Stamp</i></p>
Company Details JBS&G Australia Pty Ltd	
I hereby certify that I have undertaken the assessment of the above site and determined the Bushfire Attack Level stated above in accordance with the requirements of AS 3959-2018.	

Reliance on the assessment and determination of the Bushfire Attack Level contained in this certificate should not extend beyond a period of 12 months from the date of issue of the certificate. If this certificate was issued more than 12 months ago, it is recommended that the validity of the determination be confirmed with the Accredited Practitioner and where required an updated certificate issued.

© JBS&G

This document is and shall remain the property of JBS&G. The document may only be used for the purposes for which it was commissioned and in accordance with the Terms of Engagement for the commission. Unauthorised use of this document in any form whatsoever is prohibited

Document Status

Rev No.	Author	Reviewer		Approved for Issue	
		Name	Name	Signature	Date
Rev 0	Kaitlin Southgate (BPAD 57034, Level 1)	Zac Cockerill (BPAD 37803, Level 2)	Zac Cockerill (BPAD 37803, Level 2)		15 December 2023



Adelaide

Kaurna Country | 100 Hutt St,
Adelaide, SA 5000
T: 08 8431 7113

Brisbane

Turrbal/Yuggera Country | Level 37, 123
Eagle Street, Brisbane, QLD 4000
T: 07 3211 5350

Bunbury

Wardandi Noongar Country | 177
Spencer Street Bunbury, WA 6230
T: 08 9792 4797

Canberra

Ngunnawal Country | Level 1, The Realm
18 National Circuit Barton, ACT 2600
T: 02 6198 3278

Darwin

Larrakia Country | Suite G1, Level 1
48-50 Smith Street, Darwin NT 0800
T: 08 8943 0600

Hobart

Muwununa/Nuenon Country | Level 6,
111 Macquarie Street Hobart, TAS 7000
T: 03 6108 9054

Melbourne

Kulin Country | Level 5, 10 Queen
Street, Melbourne, VIC 3000
T: 03 9642 0599

Newcastle

Awabakal/Worimi Country | 61 / 63
Parry Street Newcastle West, NSW 2302
T: 02 8245 0300

Perth

Whadjuk Nyoongar Country | Allendale Square,
Level 9, 77 St Georges Terrace, WA 6000
T: 08 9380 3100

Sydney

Gadigal Country | Level 1, 50
Margaret Street, Sydney, NSW 2000
T: 02 8245 0300

Wollongong

Dharawal Country | Suite 1A, 280 - 286
Keira Street, Wollongong, NSW 2500
T: 02 4225 2647